

FEDERAL OPERATING PERMIT

A FEDERAL OPERATING PERMIT IS HEREBY ISSUED TO
The Dow Chemical Company

AUTHORIZING THE OPERATION OF
Dow Texas Operations Freeport
Freeport Energy Center
Other Basic Organic Chemical Manufacturing

LOCATED AT
Brazoria County, Texas
Latitude 28° 59' 27" Longitude 95° 24' 27"
Regulated Entity Number: RN100225945

This permit is issued in accordance with and subject to the Texas Clean Air Act (TCAA), Chapter 382 of the Texas Health and Safety Code and Title 30 Texas Administrative Code Chapter 122 (30 TAC Chapter 122), Federal Operating Permits. Under 30 TAC Chapter 122, this permit constitutes the permit holder's authority to operate the site and emission units listed in this permit. Operations of the site and emission units listed in this permit are subject to all additional rules or amended rules and orders of the Commission pursuant to the TCAA.

This permit does not relieve the permit holder from the responsibility of obtaining New Source Review authorization for new, modified, or existing facilities in accordance with 30 TAC Chapter 116, Control of Air Pollution by Permits for New Construction or Modification.

The site and emission units authorized by this permit shall be operated in accordance with 30 TAC Chapter 122, the general terms and conditions, special terms and conditions, and attachments contained herein.

This permit shall expire five years from the date of issuance. The renewal requirements specified in 30 TAC § 122.241 must be satisfied in order to renew the authorization to operate the site and emission units.

Permit No: Q2697 Issuance Date: August 3, 2017

For the Commission

Table of Contents

Section	Page
General Terms and Conditions	1
Special Terms and Conditions:	1
Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting.....	1
Additional Monitoring Requirements	9
New Source Review Authorization Requirements	9
Compliance Requirements.....	9
Protection of Stratospheric Ozone	11
Permit Location	11
Permit Shield (30 TAC § 122.148)	11
Attachments	13
Applicable Requirements Summary.....	14
Additional Monitoring Requirements	52
Permit Shield	60
New Source Review Authorization References	64
Appendix A	68
Acronym List	69
Appendix B	70

General Terms and Conditions

The permit holder shall comply with all terms and conditions contained in 30 TAC § 122.143 (General Terms and Conditions), 30 TAC § 122.144 (Recordkeeping Terms and Conditions), 30 TAC § 122.145 (Reporting Terms and Conditions), and 30 TAC § 122.146 (Compliance Certification Terms and Conditions).

In accordance with 30 TAC § 122.144(1), records of required monitoring data and support information required by this permit, or any applicable requirement codified in this permit, are required to be maintained for a period of five years from the date of the monitoring report, sample, or application unless a longer data retention period is specified in an applicable requirement. The five year record retention period supersedes any less stringent retention requirement that may be specified in a condition of a permit identified in the New Source Review Authorization attachment.

If the permit holder chooses to demonstrate that this permit is no longer required, a written request to void this permit shall be submitted to the Texas Commission on Environmental Quality (TCEQ) by the Responsible Official in accordance with 30 TAC § 122.161(e). The permit holder shall comply with the permit's requirements, including compliance certification and deviation reporting, until notified by the TCEQ that this permit is voided.

The permit holder shall comply with 30 TAC Chapter 116 by obtaining a New Source Review authorization prior to new construction or modification of emission units located in the area covered by this permit.

All reports required by this permit must include in the submittal a cover letter which identifies the following information: company name, TCEQ regulated entity number, air account number (if assigned), site name, area name (if applicable), and Air Permits Division permit number(s).

Special Terms and Conditions:

Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting

1. Permit holder shall comply with the following requirements:
 - A. Emission units (including groups and processes) in the Applicable Requirements Summary attachment shall meet the limitations, standards, equipment specifications, monitoring, recordkeeping, reporting, testing, and other requirements listed in the Applicable Requirements Summary attachment to assure compliance with the permit.
 - B. The textual description in the column titled "Textual Description" in the Applicable Requirements Summary attachment is not enforceable and is not deemed as a substitute for the actual regulatory language. The Textual Description is provided for information purposes only.
 - C. A citation listed on the Applicable Requirements Summary attachment, which has a notation [G] listed before it, shall include the referenced section and subsection for all commission rules, or paragraphs for all federal and state regulations and all subordinate paragraphs, subparagraphs and clauses, subclauses, and items contained within the referenced citation as applicable requirements.
 - D. When a grouped citation, notated with a [G] in the Applicable Requirements Summary, contains multiple compliance options, the permit holder must keep records of when each compliance option was used.

- E. Emission units subject to 40 CFR Part 63, Subpart DDDDD as identified in the attached Applicable Requirements Summary table are subject to 30 TAC Chapter 113, Subchapter C, §113.1130 which incorporates the 40 CFR Part 63 Subpart by reference.
- F. Emission units subject to 40 CFR Part 63, Subpart YYYY as identified in the attached Applicable Requirements Summary table are subject to 30 TAC Chapter 113, Subchapter C, § 113.1080 which incorporates the 40 CFR Part 63 Subpart by reference.
- G. For the purpose of generating emission reduction credits through 30 TAC Chapter 101, Subchapter H, Division 1 (Emission Credit Banking and Trading), the permit holder shall comply with the following requirements:
 - (i) Title 30 TAC § 101.302 (relating to General Provisions)
 - (ii) Title 30 TAC § 101.303 (relating to Emission Reduction Credit Generation Certification)
 - (iii) Title 30 TAC § 101.304 (relating to Mobile Emission Reduction Credit Generation and Certification)
 - (iv) Title 30 TAC § 101.309 (relating to Emission Credit Banking and Trading)
 - (v) The terms and conditions by which the emission limits are established to generate the reduction credit are applicable requirements of this permit
- H. The permit holder shall comply with the following 30 TAC Chapter 101, Subchapter H, Division 3 (Mass Emission Cap and Trade Program) Requirements:
 - (i) Title 30 TAC § 101.352 (relating to General Provisions)
 - (ii) Title 30 TAC § 101.353 (relating to Allocation of Allowances)
 - (iii) Title 30 TAC § 101.354 (relating to Allowance Deductions)
 - (iv) Title 30 TAC § 101.356 (relating to Allowance Banking and Trading)
 - (v) Title 30 TAC § 101.358 (relating to Emission Monitoring and Compliance Demonstration)
 - (vi) Title 30 TAC § 101.359 (relating to Reporting)
 - (vii) Title 30 TAC § 101.360 (relating to Level of Activity Certification)
 - (viii) The terms and conditions by which the emission limits are established to meet or exceed the cap are applicable requirements of this permit
- I. For the purpose of generating discrete emission reduction credits through 30 TAC Chapter 101, Subchapter H, Division 4 (Discrete Emission Credit Banking and Trading), the permit holder shall comply with the following requirements:
 - (i) Title 30 TAC § 101.372 (relating to General Provisions)
 - (ii) Title 30 TAC § 101.373 (relating to Discrete Emission Reduction Credit Generation and Certification)

- (iii) Title 30 TAC § 101.374 (relating to Mobile Discrete Emission Reduction Credit Generation and Certification)
 - (iv) Title 30 TAC § 101.378 (relating to Discrete Emission Credit Banking and Trading)
 - (v) The terms and conditions by which the emission limits are established to generate the discrete reduction credit are applicable requirements of this permit
 - J. The permit holder shall comply with the following 30 TAC Chapter 101, Subchapter H, Division 6 (Highly Reactive Volatile Organic Compound Emissions Cap and Trade Program) requirements:
 - (i) Title 30 TAC § 101.392 (relating to Exemptions)
 - (ii) Title 30 TAC § 101.401 (relating to Level of Activity Certification)
- 2. The permit holder shall comply with the following sections of 30 TAC Chapter 101 (General Air Quality Rules):
 - A. Title 30 TAC § 101.1 (relating to Definitions), insofar as the terms defined in this section are used to define the terms used in other applicable requirements
 - B. Title 30 TAC § 101.3 (relating to Circumvention)
 - C. Title 30 TAC § 101.8 (relating to Sampling), if such action has been requested by the TCEQ
 - D. Title 30 TAC § 101.9 (relating to Sampling Ports), if such action has been requested by the TCEQ
 - E. Title 30 TAC § 101.10 (relating to Emissions Inventory Requirements)
 - F. Title 30 TAC § 101.201 (relating to Emission Event Reporting and Recordkeeping Requirements)
 - G. Title 30 TAC § 101.211 (relating to Scheduled Maintenance, Start-up, and Shutdown Reporting and Recordkeeping Requirements)
 - H. Title 30 TAC § 101.221 (relating to Operational Requirements)
 - I. Title 30 TAC § 101.222 (relating to Demonstrations)
 - J. Title 30 TAC § 101.223 (relating to Actions to Reduce Excessive Emissions)
- 3. Permit holder shall comply with the following requirements of 30 TAC Chapter 111:
 - A. Visible emissions from stationary vents with a flow rate of less than 100,000 actual cubic feet per minute and constructed after January 31, 1972 that are not listed in the Applicable Requirements Summary attachment for 30 TAC Chapter 111, Subchapter A, Division 1, shall not exceed 20% opacity averaged over a six-minute period. The permit holder shall comply with the following requirements for stationary vents at the site subject to this standard:
 - (i) Title 30 TAC § 111.111(a)(1)(B) (relating to Requirements for Specified Sources)

- (ii) Title 30 TAC § 111.111(a)(1)(E)
- (iii) Title 30 TAC § 111.111(a)(1)(F)(i), (ii), (iii), or (iv)
- (iv) For emission units with vent emissions subject to 30 TAC § 111.111(a)(1)(B), complying with 30 TAC § 111.111(a)(1)(F)(ii), (iii), or (iv), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO_x, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146. These periodic monitoring requirements do not apply to vents that are not capable of producing visible emissions such as vents that emit only colorless VOCs; vents from non-fuming liquids; vents that provide passive ventilation, such as plumbing vents; or vent emissions from any other source that does not obstruct the transmission of light. Vents, as specified in the "Applicable Requirements Summary" attachment, that are subject to the emission limitation of 30 TAC § 111.111(a)(1)(B) are not subject to the following periodic monitoring requirements:
 - (1) An observation of stationary vents from emission units in operation shall be conducted at least once during each calendar quarter unless the emission unit is not operating for the entire quarter.
 - (2) For stationary vents from a combustion source, if an alternative to the normally fired fuel is fired for a period greater than or equal to 24 consecutive hours, the permit holder shall conduct an observation of the stationary vent for each such period to determine if visible emissions are present. If such period is greater than 3 months, observations shall be conducted once during each quarter. Supplementing the normally fired fuel with natural gas or fuel gas to increase the net heating value to the minimum required value does not constitute creation of an alternative fuel.
 - (3) Records of all observations shall be maintained.
 - (4) Visible emissions observations of emission units operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of emission units operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions observations shall be made during times when the activities described in 30 TAC § 111.111(a)(1)(E) are not taking place. Visible emissions shall be determined with each stationary vent in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each stationary vent during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.
 - (5) Compliance Certification:

- (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(1) and (a)(1)(B).
 - (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(1)(F) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.
 - (c) Some vents may be subject to multiple visible emission or monitoring requirements. All credible data must be considered when certifying compliance with this requirement even if the observation or monitoring was performed to demonstrate compliance with a different requirement.
- B. Certification of opacity readers determining opacities under Method 9 (as outlined in 40 CFR Part 60, Appendix A) to comply with opacity monitoring requirements shall be accomplished by completing the Visible Emissions Evaluators Course, or approved agency equivalent, no more than 180 days before the opacity reading.
- C. For emission units with contributions from uncombined water, the permit holder shall comply with the requirements of 30 TAC § 111.111(b).
- D. Emission limits on nonagricultural processes, except for the steam generators specified in 30 TAC § 111.153, shall comply with the following requirements:
 - (i) Emissions of PM from any source may not exceed the allowable rates as required in 30 TAC § 111.151(a) (relating to Allowable Emissions Limits)
 - (ii) Sources with an effective stack height (h_e) less than the standard effective stack height (H_e), must reduce the allowable emission level by multiplying it by $[h_e/H_e]^2$ as required in 30 TAC § 111.151(b)
 - (iii) Effective stack height shall be calculated by the equation specified in 30 TAC § 111.151(c)
- 4. For storage vessels maintaining working pressure as specified in 30 TAC Chapter 115, Subchapter B, Division 1: Storage of Volatile Organic Compounds, the permit holder shall comply with the requirements of 30 TAC § 115.112(e)(1).
- 5. The permit holder shall comply with the following requirements of 30 TAC Chapter 115, Subchapter H, Division 1 for pressure relief devices not controlled by a flare:

- A. Title 30 TAC § 115.725(c)
 - B. Title 30 TAC § 115.725(c)(1), (c)(1)(A) - (C)
 - C. Title 30 TAC § 115.725(c)(2)
 - D. Title 30 TAC § 115.725(c)(3), (c)(3)(A) - (E)
 - E. Title 30 TAC § 115.725(c)(4)
 - F. Title 30 TAC § 115.725(l)
 - G. Title 30 TAC § 115.726(c), (c)(1) - (4)
6. The permit holder shall comply with the requirements of 30 TAC § 115.726(e)(3)(A) for vent streams having no potential to emit HRVOC.
7. The permit holder shall comply with the following requirements for units subject to any subpart of 40 CFR Part 60, unless otherwise stated in the applicable subpart:
- A. Title 40 CFR § 60.7 (relating to Notification and Recordkeeping)
 - B. Title 40 CFR § 60.8 (relating to Performance Tests)
 - C. Title 40 CFR § 60.11 (relating to Compliance with Standards and Maintenance Requirements)
 - D. Title 40 CFR § 60.12 (relating to Circumvention)
 - E. Title 40 CFR § 60.13 (relating to Monitoring Requirements)
 - F. Title 40 CFR § 60.14 (relating to Modification)
 - G. Title 40 CFR § 60.15 (relating to Reconstruction)
 - H. Title 40 CFR § 60.19 (relating to General Notification and Reporting Requirements)
8. The permit holder shall comply with the following requirements for units subject to any subpart of 40 CFR Part 61, unless otherwise stated in the applicable subpart:
- A. Title 40 CFR § 61.05 (relating to Prohibited Activities)
 - B. Title 40 CFR § 61.07 (relating to Application for Approval of Construction or Modification)
 - C. Title 40 CFR § 61.09 (relating to Notification of Start-up)
 - D. Title 40 CFR § 61.10 (relating to Source Reporting and Request Waiver)
 - E. Title 40 CFR § 61.12 (relating to Compliance with Standards and Maintenance Requirements)
 - F. Title 40 CFR § 61.13 (relating to Emissions Tests and Waiver of Emission Tests)
 - G. Title 40 CFR § 61.14 (relating to Monitoring Requirements)

- H. Title 40 CFR § 61.15 (relating to Modification)
 - I. Title 40 CFR § 61.19 (relating to Circumvention)
9. For facilities where total annual benzene quantity from waste is greater than or equal to 10 megagrams per year and subject to emission standards in 40 CFR Part 61, Subpart FF, the permit holder shall comply with the following requirements:
- A. Title 40 CFR § 61.342(c)(1)(i) - (iii) (relating to Standards: General)
 - B. For exempting waste streams:
 - (i) Title 40 CFR § 61.342(c)(3)(ii)(A) - (C) (relating to Standards: General)
 - C. Title 40 CFR § 61.342(f)(1), and (2) (relating to Standards: General)
 - D. Title 40 CFR § 61.342(g) (relating to Standards: General)
 - E. Title 40 CFR § 61.350(a) and (b) (relating to Standards: Delay of Repair)
 - F. Title 40 CFR § 61.355(a)(1)(iii), (a)(2), (a)(6), (b), and (c)(1) - (3) (relating to Test Methods, Procedures, and Compliance Provisions)
 - G. Title 40 CFR § 61.355(j) (relating to Test Methods, Procedures, and Compliance Provisions), for calculation procedures
 - H. Title 40 CFR § 61.356(a) (relating to Recordkeeping Requirements)
 - I. Title 40 CFR § 61.356(b), and (b)(1) (relating to Recordkeeping Requirements)
 - J. Title 40 CFR § 61.356(b)(2)(i) - (ii) (relating to Recordkeeping Requirements)
 - K. Title 40 CFR § 61.356(b)(5) (relating to Recordkeeping Requirements)
 - L. Title 40 CFR § 61.356(c) (relating to Recordkeeping Requirements)
 - M. Title 40 CFR § 61.357(a), (d)(1), (d)(2) (d)(6) and (d)(8) (relating to Reporting Requirements)
 - N. Title 40 CFR § 61.357(d)(3) (relating to Reporting Requirements)
10. For facilities with containers subject to emission standards in 40 CFR Part 61, Subpart FF, the permit holder shall comply with the following requirements:
- A. Title 40 CFR § 61.345(a)(1) - (3), (b), and (c) (relating to Standards: Containers)
 - B. Title 40 CFR § 61.355(h) (relating to Test Methods, Procedures and Compliance Provisions)
 - C. Title 40 CFR § 61.356(g) (relating to Recordkeeping Requirements)
 - D. Title 40 CFR § 61.356(h) (relating to Recordkeeping Requirements)

11. The permit holder shall comply with the requirements of 30 TAC Chapter 113, Subchapter C, § 113.100 for units subject to any subpart of 40 CFR Part 63, unless otherwise stated in the applicable subpart.
12. For the transfer of site remediation materials subject to 40 CFR Part 63, Subpart GGGGG off-site to another facility, the permit holder shall comply with the following requirements (Title 30 TAC, Subchapter C, § 113.1160 incorporated by reference):
 - A. Title 40 CFR § 63.7936(a), for the transfer of site remediation materials
 - B. Title 40 CFR § 63.7936(b)(1), for transfer to a landfill or land disposal unit
 - C. Title 40 CFR § 63.7936(b)(2), for transfer to a facility subject to 40 CFR Part 63, Subpart DD
 - D. Title 40 CFR § 63.7936(b)(3), (b)(3)(i) - (iv), for transfer to a facility managing the site remediation material according to the requirements of 40 CFR Part 63, Subpart GGGGG
13. For containers managing remediation materials subject to 40 CFR Part 63, Subpart GGGGG, the permit holder shall comply with the following requirements (Title 30 TAC Chapter 113, Subchapter C, § 113.1160 incorporated by reference):
 - A. Title 40 CFR § 63.922(b)(1) - (3), (c), (d), (d)(1) - (5), (e), and (f), (f)(1) - (4) (relating to Standards - Container Level 1 Controls)
 - B. Title 40 CFR § 63.923(b)(1) - (3), (c), (d), (d)(1) - (5), (e), and (f), (f)(1) - (4) (relating to Standards - Container Level 2 Controls)
 - C. Title 40 CFR § 63.925(a)(1) - (8), and (b)(1) - (3) (relating to Test Methods and Procedures)
 - D. Title 40 CFR § 63.926(a)(1) - (3) (relating to Inspection and Monitoring Requirements)
 - E. Title 40 CFR § 63.7901(b) and (b)(1), for initial demonstration of compliance
 - F. Title 40 CFR § 63.7901(b)(2), for initial demonstration of compliance
 - G. Title 40 CFR § 63.7901(c), (c)(1), and (c)(2), for initial demonstration of compliance
 - H. Title 40 CFR § 63.7901(d), and (d)(1) - (4), for initial demonstration of compliance
 - I. Title 40 CFR § 63.7903(b) and (b)(1), for continuous demonstration of compliance
 - J. Title 40 CFR § 63.7903(b)(2), (b)(2)(i), (b)(2)(ii), for continuous demonstration of compliance
 - K. Title 40 CFR § 63.7903(c)(4), (c)(4)(i), and (c)(4)(ii), for continuous demonstration of compliance
 - L. Title 40 CFR § 63.7903(d)(5), (d)(5)(i), and (d)(5)(ii), for continuous demonstration of compliance
 - M. Title 40 CFR § 63.7952(c), for recordkeeping

Additional Monitoring Requirements

14. The permit holder shall comply with the periodic monitoring requirements as specified in the attached "Periodic Monitoring Summary" upon issuance of the permit. Except for, as applicable, monitoring malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), the permit holder shall conduct all monitoring in continuous operation (or shall collect data at all required intervals) at all times that the pollutant-specific emissions unit is operating. The permit holder may elect to collect monitoring data on a more frequent basis and average the data, consistent with the averaging time specified in the "Periodic Monitoring Summary," for purposes of determining whether a deviation has occurred. However, the additional data points must be collected on a regular basis. In no event shall data be collected and used in particular instances to avoid reporting deviations. Deviations shall be reported according to 30 TAC § 122.145 (Reporting Terms and Conditions).

New Source Review Authorization Requirements

15. Permit holder shall comply with the requirements of New Source Review authorizations issued or claimed by the permit holder for the permitted area, including permits, permits by rule, standard permits, flexible permits, special permits, permits for existing facilities including Voluntary Emissions Reduction Permits and Electric Generating Facility Permits issued under 30 TAC Chapter 116, Subchapter I, or special exemptions referenced in the New Source Review Authorization References attachment. These requirements:
 - A. Are incorporated by reference into this permit as applicable requirements
 - B. Shall be located with this operating permit
 - C. Are not eligible for a permit shield
16. The permit holder shall comply with the general requirements of 30 TAC Chapter 106, Subchapter A or the general requirements, if any, in effect at the time of the claim of any PBR.
17. The permit holder shall maintain records to demonstrate compliance with any emission limitation or standard that is specified in a permit by rule (PBR) or Standard Permit listed in the New Source Review Authorizations attachment. The records shall yield reliable data from the relevant time period that are representative of the emission unit's compliance with the PBR or Standard Permit. These records may include, but are not limited to, production capacity and throughput, hours of operation, safety data sheets (SDS), chemical composition of raw materials, speciation of air contaminant data, engineering calculations, maintenance records, fugitive data, performance tests, capture/control device efficiencies, direct pollutant monitoring (CEMS, COMS, or PEMS), or control device parametric monitoring. These records shall be made readily accessible and available as required by 30 TAC § 122.144. Any monitoring or recordkeeping data indicating noncompliance with the PBR or Standard Permit shall be considered and reported as a deviation according to 30 TAC § 122.145 (Reporting Terms and Conditions).

Compliance Requirements

18. The permit holder shall certify compliance in accordance with 30 TAC § 122.146. The permit holder shall comply with 30 TAC § 122.146 using at a minimum, but not limited to, the continuous or intermittent compliance method data from monitoring, recordkeeping, reporting, or testing required by the permit and any other credible evidence or information. The certification period may not exceed 12 months and the certification must be submitted within 30 days after the end of the period being certified.

19. Permit holder shall comply with the following 30 TAC Chapter 117 requirements:
- A. The permit holder shall comply with the compliance schedules and submit written notification to the TCEQ Executive Director as required in 30 TAC Chapter 117, Subchapter H, Division 1:
 - (i) For sources in the Houston-Galveston-Brazoria Nonattainment area, 30 TAC § 117.9020:
 - (1) Title 30 TAC § 117.9020(2)(A), (C), and (D)
 - (ii) For electric generating facilities in the Houston-Galveston-Brazoria Nonattainment area, 30 TAC § 117.9020(2)(B)
 - B. The permit holder shall comply with the Initial Control Plan unit listing requirement in 30 TAC § 117.350(c) and (c)(1).
 - C. The permit holder shall comply with the requirements of 30 TAC § 117.354 for Final Control Plan Procedures for Attainment Demonstration Emission Specifications and 30 TAC § 117.356 for Revision of Final Control Plan.
20. Use of Emission Credits to comply with applicable requirements:
- A. Unless otherwise prohibited, the permit holder may use emission credits to comply with the following applicable requirements listed elsewhere in this permit:
 - (i) Title 30 TAC Chapter 115
 - (ii) Title 30 TAC Chapter 117
 - (iii) Offsets for Title 30 TAC Chapter 116
 - B. The permit holder shall comply with the following requirements in order to use the emission credits to comply with the applicable requirements:
 - (i) The permit holder must notify the TCEQ according to 30 TAC § 101.306(c)-(d)
 - (ii) The emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 1
 - (iii) The executive director has approved the use of the credit according to 30 TAC § 101.306(c)-(d)
 - (iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.302(g) and 30 TAC Chapter 122
 - (v) Title 30 TAC § 101.305 (relating to Emission Reductions Achieved Outside the United States)
21. Use of Discrete Emission Credits to comply with the applicable requirements:
- A. Unless otherwise prohibited, the permit holder may use discrete emission credits to comply with the following applicable requirements listed elsewhere in this permit:

- (i) Title 30 TAC Chapter 115
 - (ii) Title 30 TAC Chapter 117
 - (iii) If applicable, offsets for Title 30 TAC Chapter 116
 - (iv) Temporarily exceed state NSR permit allowables
- B. The permit holder shall comply with the following requirements in order to use the credit to comply with the applicable requirements:
- (i) The permit holder must notify the TCEQ according to 30 TAC § 101.376(d)
 - (ii) The discrete emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 4
 - (iii) The executive director has approved the use of the discrete emission credits according to 30 TAC § 101.376(d)(1)(A)
 - (iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.372(h) and 30 TAC Chapter 122
 - (v) Title 30 TAC § 101.375 (relating to Emission Reductions Achieved Outside the United States)

Protection of Stratospheric Ozone

22. Permit holders at a site subject to Title VI of the FCAA Amendments shall meet the following requirements for protection of stratospheric ozone:
- A. Any on site servicing, maintenance, and repair on refrigeration and nonmotor vehicle air-conditioning appliances using ozone-depleting refrigerants or non-exempt substitutes shall be conducted in accordance with 40 CFR Part 82, Subpart F. Permit holders shall ensure that repairs on or refrigerant removal from refrigeration and nonmotor vehicle air-conditioning appliances using ozone-depleting refrigerants are performed only by properly certified technicians using certified equipment. Records shall be maintained as required by 40 CFR Part 82, Subpart F.
 - B. The permit holder shall comply with 40 CFR Part 82, Subpart F related to the disposal requirements for appliances using Class I or Class II (ozone-depleting) substances or non-exempt substitutes as specified in 40 CFR §§ 82.150 - 82.166 and the applicable Part 82 Appendices.

Permit Location

23. The permit holder shall maintain a copy of this permit and records related to requirements listed in this permit on site.

Permit Shield (30 TAC § 122.148)

24. A permit shield is granted for the emission units, groups, or processes specified in the attached "Permit Shield." Compliance with the conditions of the permit shall be deemed compliance with the specified potentially applicable requirements or specified potentially applicable state-only

requirements listed in the attachment "Permit Shield." Permit shield provisions shall not be modified by the executive director until notification is provided to the permit holder. No later than 90 days after notification of a change in a determination made by the executive director, the permit holder shall apply for the appropriate permit revision to reflect the new determination. Provisional terms are not eligible for this permit shield. Any term or condition, under a permit shield, shall not be protected by the permit shield if it is replaced by a provisional term or condition or the basis of the term and condition changes.

Attachments

Applicable Requirements Summary

Additional Monitoring Requirements

Permit Shield

New Source Review Authorization References

Applicable Requirements Summary

Unit Summary	15
---------------------------	-----------

Applicable Requirements Summary	21
--	-----------

Note: A “none” entry may be noted for some emission sources in this permit’s “Applicable Requirements Summary” under the heading of “Monitoring and Testing Requirements” and/or “Recordkeeping Requirements” and/or “Reporting Requirements.” Such a notation indicates that there are no requirements for the indicated emission source as identified under the respective column heading(s) for the stated portion of the regulation when the emission source is operating under the conditions of the specified SOP Index Number. However, other relevant requirements pursuant to 30 TAC Chapter 122 including Recordkeeping Terms and Conditions (30 TAC § 122.144), Reporting Terms and Conditions (30 TAC § 122.145), and Compliance Certification Terms and Conditions (30 TAC § 122.146) continue to apply.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
A153P3STLO	STORAGE TANKS/VESSELS	N/A	R5112-01	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
A153PSP39	VOLATILE ORGANIC COMPOUND WATER SEPARATORS	N/A	R5131-01	30 TAC Chapter 115, Water Separation	No changing attributes.
A25SILRT25	LOADING/UNLOADING OPERATIONS	N/A	R5211-01	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
A25SISTT25	STORAGE TANKS/VESSELS	N/A	R5112-01	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
A25SISTT25	STORAGE TANKS/VESSELS	N/A	61FF-01	40 CFR Part 61, Subpart FF	No changing attributes.
B106PSC1	SOLVENT DEGREASING MACHINES	N/A	R5412-01	30 TAC Chapter 115, Degreasing Processes	No changing attributes.
B106PSC1	CLEANING/DEPAINTING OPERATION	N/A	R5460-01	30 TAC Chapter 115, Subchapter E, Division 6	No changing attributes.
B246PSC412	SOLVENT DEGREASING MACHINES	N/A	R5412-01	30 TAC Chapter 115, Degreasing Processes	No changing attributes.
B246PSC412	CLEANING/DEPAINTING OPERATION	N/A	R5460-01	30 TAC Chapter 115, Subchapter E, Division 6	No changing attributes.
B4SILRD500	LOADING/UNLOADING OPERATIONS	N/A	R5211-01	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
B4SISTD500	STORAGE TANKS/VESSELS	N/A	R5112-01	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
B4SISTD500	STORAGE TANKS/VESSELS	N/A	61FF-01	40 CFR Part 61, Subpart FF	No changing attributes.
B56CR96	EMISSION POINTS/STATIONARY	N/A	R1111-01	30 TAC Chapter 111, Visible Emissions	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
	VENTS/PROCESS VENTS				
B56CR96	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R5720-01	30 TAC Chapter 115, HRVOC Vent Gas	No changing attributes.
B56P9DB96	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	R7ICI-01	30 TAC Chapter 117, Subchapter B	No changing attributes.
B56P9GT96	STATIONARY TURBINES	N/A	R7310-01	30 TAC Chapter 117, Subchapter B	No changing attributes.
B56P9GT96	STATIONARY TURBINES	N/A	60KKKK-01	40 CFR Part 60, Subpart KKKK	No changing attributes.
B56P9GT96	STATIONARY TURBINES	N/A	63YYYY-01	40 CFR Part 63, Subpart YYYY	No changing attributes.
B56P9SB1	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	R7ICI-01	30 TAC Chapter 117, Subchapter B	No changing attributes.
B56P9SB1	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	60Db-01	40 CFR Part 60, Subpart Db	No changing attributes.
B56P9SB1	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	63DDDD-01	40 CFR Part 63, Subpart DDDD	No changing attributes.
B56P9SB2	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	R7ICI-01	30 TAC Chapter 117, Subchapter B	No changing attributes.
B56P9SB2	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	60Db-01	40 CFR Part 60, Subpart Db	No changing attributes.
B56P9SB2	BOILERS/STEAM	N/A	63DDDD-01	40 CFR Part 63, Subpart	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
	GENERATORS/STEAM GENERATING UNITS			DDDDD	
B56P9SB3	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	R7ICI-01	30 TAC Chapter 117, Subchapter B	No changing attributes.
B56P9SB3	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	60Db-01	40 CFR Part 60, Subpart Db	No changing attributes.
B56P9SB3	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	63DDDDD-01	40 CFR Part 63, Subpart DDDDD	No changing attributes.
B56P9SB4	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	R7ICI-01	30 TAC Chapter 117, Subchapter B	No changing attributes.
B56P9SB4	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	60Db-01	40 CFR Part 60, Subpart Db	No changing attributes.
B56P9SB4	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	63DDDDD-01	40 CFR Part 63, Subpart DDDDD	No changing attributes.
B56SB1	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1111-01	30 TAC Chapter 111, Visible Emissions	No changing attributes.
B56SB1	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R5720-01	30 TAC Chapter 115, HRVOC Vent Gas	No changing attributes.
B56SB2	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1111-01	30 TAC Chapter 111, Visible Emissions	No changing attributes.
B56SB2	EMISSION	N/A	R5720-01	30 TAC Chapter 115,	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
	POINTS/STATIONARY VENTS/PROCESS VENTS			HRVOC Vent Gas	
B56SB3	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1111-01	30 TAC Chapter 111, Visible Emissions	No changing attributes.
B56SB3	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R5720-01	30 TAC Chapter 115, HRVOC Vent Gas	No changing attributes.
B56SB4	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1111-01	30 TAC Chapter 111, Visible Emissions	No changing attributes.
B56SB4	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R5720-01	30 TAC Chapter 115, HRVOC Vent Gas	No changing attributes.
B56SEP001	VOLATILE ORGANIC COMPOUND WATER SEPARATORS	N/A	R5131-01	30 TAC Chapter 115, Water Separation	No changing attributes.
B56ST190	STORAGE TANKS/VESSELS	N/A	61FF-01	40 CFR Part 61, Subpart FF	No changing attributes.
B56ST290	STORAGE TANKS/VESSELS	N/A	61FF-01	40 CFR Part 61, Subpart FF	No changing attributes.
B56TL001	LOADING/UNLOADING OPERATIONS	N/A	R5211-01	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
B664PSP4A	VOLATILE ORGANIC COMPOUND WATER SEPARATORS	N/A	R5131-01	30 TAC Chapter 115, Water Separation	No changing attributes.
B664PSP4B	VOLATILE ORGANIC COMPOUND WATER SEPARATORS	N/A	R5131-01	30 TAC Chapter 115, Water Separation	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
BM54SILR30	LOADING/UNLOADING OPERATIONS	N/A	R5211-01	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
BM54SIST30	STORAGE TANKS/VESSELS	N/A	R5112-01	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
BM54SIST30	STORAGE TANKS/VESSELS	N/A	61FF-01	40 CFR Part 61, Subpart FF	No changing attributes.
BP4ST4003	STORAGE TANKS/VESSELS	N/A	R5112-01	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
PROPWRA	CLEANING/DEPAINTING OPERATION	N/A	R5460-01	30 TAC Chapter 115, Subchapter E, Division 6	Compliance Demonstration = Limiting VOC content of the cleaning solution to 0.42 lb VOC/gal of solution, as applied.
PROPWRA	CLEANING/DEPAINTING OPERATION	N/A	R5460-02	30 TAC Chapter 115, Subchapter E, Division 6	Compliance Demonstration = Limiting the composite partial vapor pressure of the cleaning solution to 8.0 millimeters of mercury at 20 degrees Celsius (68 degrees Fahrenheit).
PROPW RB	CLEANING/DEPAINTING OPERATION	N/A	R5460-01	30 TAC Chapter 115, Subchapter E, Division 6	Compliance Demonstration = Limiting VOC content of the cleaning solution to 0.42 lb VOC/gal of solution, as applied.
PROPW RB	CLEANING/DEPAINTING OPERATION	N/A	R5460-02	30 TAC Chapter 115, Subchapter E, Division 6	Compliance Demonstration = Limiting the composite partial vapor pressure of the cleaning solution to 8.0 millimeters of mercury at 20 degrees Celsius (68 degrees Fahrenheit).
PROPWROC	CLEANING/DEPAINTING OPERATION	N/A	R5460-01	30 TAC Chapter 115, Subchapter E, Division 6	Compliance Demonstration = Limiting VOC content of the cleaning

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					solution to 0.42 lb VOC/gal of solution, as applied.
PROPWROC	CLEANING/DEPAINTING OPERATION	N/A	R5460-02	30 TAC Chapter 115, Subchapter E, Division 6	Compliance Demonstration = Limiting the composite partial vapor pressure of the cleaning solution to 8.0 millimeters of mercury at 20 degrees Celsius (68 degrees Fahrenheit).

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
A153P3STL O	EU	R5112-01	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
A153PSP39	EU	R5131-01	VOC	30 TAC Chapter 115, Water Separation	§ 115.137(a)(2) [G]§ 115.132(a)(4)	Any single or multiple compartment VOC water separator which separates materials having a true vapor pressure of VOC < .5 psia obtained from any equipment is exempt from §115.132(a).	[G]§ 115.135(a) § 115.136(a)(1) § 115.136(a)(3) § 115.136(a)(4)	§ 115.136(a)(1) § 115.136(a)(3) § 115.136(a)(4)	None
A25SILRT25	EU	R5211-01	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.213(b) § 115.212(a)(3)(B) § 115.212(a)(3)(E) § 115.213(b)(1) § 115.213(b)(4) [G]§ 115.213(b)(6) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(ii)	General loading - 90% overall control option in the covered non-attainment counties. As an alternative operations may elect to achieve a 90% overall control of emissions at the account.	§ 115.212(a)(3)(B) § 115.213(b) § 115.213(b)(1) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) § 115.215(4) § 115.215(9)	§ 115.213(b)(1) § 115.216 § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	§ 115.213(b)(1) § 115.213(b)(2) § 115.213(b)(3) § 115.213(b)(4)
A25SISTT25	EU	R5112-01	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
A25SISTT25	EU	61FF-01	Benzene	40 CFR Part 61, Subpart FF	§ 61.343(b)(2) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(b)(3) § 61.343(c) § 61.343(d)	The owner/operator shall install, operate, and maintain a fixed roof as specified in §61.343(a)(1)(i).	§ 61.343(a)(1)(i)(A) § 61.343(c)	§ 61.356(d) § 61.356(g)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
B106PSC1	EU	R5412-01	VOC	30 TAC Chapter 115, Degreasing Processes	§ 115.412(1) § 115.411(1) § 115.411(2) [G]§ 115.412(1)(A) § 115.412(1)(C) § 115.412(1)(D) [G]§ 115.412(1)(F)	Cold solvent cleaning. No person shall own or operate a system utilizing a VOC for the cold solvent cleaning of objects without the controls listed in §115.412(1)(A)-(F).	[G]§ 115.415(1) § 115.415(3) ** See Periodic Monitoring Summary	None	None
B106PSC1	PRO	R5460-01	VOC	30 TAC Chapter 115, Subchapter E, Division 6	[G]§ 115.461(c)	A solvent cleaning operation is exempt from this division if the process or operation that the solvent cleaning operation is associated with is subject to another division in this chapter and the VOC emissions from the solvent cleaning operation are controlled in accordance with an emission specification or control requirement of the division that the process or operation is subject to. §115.461(c)(1)-(2)	None	§ 115.468(b)(2) § 115.468(b)(3) § 115.468(b)(5)	None
B246PSC412	EU	R5412-01	VOC	30 TAC Chapter 115, Degreasing Processes	§ 115.412(1) § 115.411(1) § 115.411(2) [G]§ 115.412(1)(A) § 115.412(1)(C) § 115.412(1)(D) [G]§ 115.412(1)(F)	Cold solvent cleaning. No person shall own or operate a system utilizing a VOC for the cold solvent cleaning of objects without the controls listed in §115.412(1)(A)-(F).	[G]§ 115.415(1) § 115.415(3) ** See Periodic Monitoring Summary	None	None
B246PSC412	PRO	R5460-01	VOC	30 TAC Chapter 115, Subchapter E, Division 6	[G]§ 115.461(c)	A solvent cleaning operation is exempt from this division if the process or operation that the solvent cleaning operation is associated with is subject to another division in this chapter and the VOC emissions from the solvent	None	§ 115.468(b)(2) § 115.468(b)(3) § 115.468(b)(5)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						cleaning operation are controlled in accordance with an emission specification or control requirement of the division that the process or operation is subject to. §115.461(c)(1)-(2)			
B4SILRD500	EU	R5211-01	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.213(b) § 115.212(a)(3)(B) § 115.212(a)(3)(E) § 115.213(b)(1) § 115.213(b)(4) [G]§ 115.213(b)(6) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(ii)	General loading - 90% overall control option in the covered non-attainment counties. As an alternative operations may elect to achieve a 90% overall control of emissions at the account.	§ 115.212(a)(3)(B) § 115.213(b) § 115.213(b)(1) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) § 115.215(4) § 115.215(9)	§ 115.213(b)(1) § 115.216 § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	§ 115.213(b)(1) § 115.213(b)(2) § 115.213(b)(3) § 115.213(b)(4)
B4SISTD500	EU	R5112-01	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
B4SISTD500	EU	61FF-01	Benzene	40 CFR Part 61, Subpart FF	§ 61.343(b)(2) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(b)(3) § 61.343(c) § 61.343(d)	The owner/operator shall install, operate, and maintain a fixed roof as specified in §61.343(a)(1)(i).	§ 61.343(a)(1)(i)(A) § 61.343(c)	§ 61.356(d) § 61.356(g)	None
B56CR96	EP	R1111-01	PM (Opacity)	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(C) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 15% averaged over a six minute period for any source with a total flow rate of at least	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						100,000 acfm unless a CEMS is installed.			
B56CR96	EP	R5720-01	Highly Reactive VOC	30 TAC Chapter 115, HRVOC Vent Gas	§ 115.727(c)(2)	A vent gas stream that has the potential to emit HRVOCs, but has a concentration less than 100 ppmv at all times or has a maximum potential flow rate equal to or less than 100 dry standard cubic feet per hour is exempt from this division with the exception of § 115.726(e)(3)(A) of this title. The maximum potential HRVOC emissions for the sum of all vent gas streams claimed under this exemption, must be less for the account specified in § 115.722(a) or (b) of this title than 0.5 tpy.	None	§ 115.726(e)(3)(A) § 115.726(j)(2)	None
B56P9DB96	EU	R7ICI-01	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(A) § 117.310(c)(3) § 117.340(f)(1) § 117.8120	CO emissions must not exceed 400 ppmv at 3.0% O ₂ , dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(3) § 117.335(g) § 117.340(a)(2)(B) § 117.340(b)(1) § 117.340(b)(3) § 117.340(e) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B)	§ 117.345(a) § 117.345(f) [G]§ 117.345(f)(2) § 117.345(f)(7) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(B)(iii)) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) § 117.8120(1) § 117.8120(1)(A)		§ 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)
B56P9DB96	EU	R7ICI-01	NH ₃	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(2) § 117.310(c)(2)(A)	For boilers that inject urea or ammonia into the exhaust stream for NO _x control, ammonia emissions must not exceed 10 ppmv at 3.0% O ₂ , dry.	§ 117.335(a)(2) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(b)(1) § 117.340(b)(3) § 117.340(d) § 117.8000(b) § 117.8000(c) § 117.8000(c)(3) § 117.8000(c)(4) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8130 § 117.8130(1)	§ 117.345(a) § 117.345(f) § 117.345(f)(11) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
B56P9DB96	EU	R7ICI-01	NO _x	30 TAC Chapter	§ 117.310(d)(3)	An owner or operator may	§ 117.320(d)	§ 117.320(f)	§ 117.320(g)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
				117, Subchapter B	§ 117.310(a) § 117.310(a)(1)(A) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.320(a) § 117.320(b) [G]§ 117.320(c) § 117.320(i) § 117.320(j) § 117.320(k) § 117.340(f)(1) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.320(e) § 117.320(h) § 117.320(k) [G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(1) § 117.335(g) § 117.340(a)(2)(B) § 117.340(b)(1) § 117.340(b)(3) § 117.340(c)(1) [G]§ 117.340(c)(3) [G]§ 117.340(f)(2) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(i) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)	§ 117.345(a) § 117.345(f) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
B56P9GT96	EU	R7310-01	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(10)(A) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.320(a) § 117.320(b) [G]§ 117.320(c) § 117.320(i) § 117.320(j) § 117.320(k) § 117.340(f)(1) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	§ 117.320(d) [G]§ 117.320(e) § 117.320(h) § 117.320(k) [G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(g) § 117.340(a)(2)(B) § 117.340(c)(1) [G]§ 117.340(c)(3) [G]§ 117.340(f)(2) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(i) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)	§ 117.320(f) § 117.345(a) § 117.345(f) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.320(g) § 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)
B56P9GT96	EU	R7310-01	CO	30 TAC Chapter	§ 117.310(c)(1)	CO emissions must not	[G]§ 117.335(a)(1)	§ 117.345(a)	§ 117.335(b)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
				117, Subchapter B	§ 117.310(c)(1)(A) § 117.340(f)(1)	exceed 400 ppmv at 3.0% O ₂ , dry basis.	§ 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(3) § 117.335(g) § 117.340(a)(2)(B) § 117.340(e) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(iii) § 117.8100(a)(1)(B)(iii)) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) § 117.8120 § 117.8120(1) § 117.8120(1)(A)	§ 117.345(f) [G]§ 117.345(f)(2) § 117.345(f)(7) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)
B56P9GT96	EU	R7310-01	NH ₃	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(2) § 117.310(c)(2)(A)	For stationary gas turbines that inject urea or ammonia into the exhaust stream for NO _x control, ammonia emissions must not exceed	§ 117.335(a)(2) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e)	§ 117.345(a) § 117.345(f) § 117.345(f)(11) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						10 ppmv at 15% O ₂ , dry.	§ 117.335(g) § 117.340(d) § 117.8000(b) § 117.8000(c) § 117.8000(c)(3) § 117.8000(c)(4) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8130 § 117.8130(1)		[G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
B56P9GT96	EU	60KKKK-01	NO _x	40 CFR Part 60, Subpart KKKK	§ 60.4320(a)-Table 1 § 60.4320(a) § 60.4320(b) § 60.4325 § 60.4333(a) § 60.4333(b)(1) § 60.4335(b)(1) § 60.4335(b)(2) § 60.4335(b)(3) [G]§ 60.4345	New turbine firing natural gas with a heat input at peak load greater than 50 MMBtu/h and less than or equal to 850 MMBtu/h must meet the nitrogen oxides emission standard of 150 ng/J of useful output (1.2 lb/MWh).	§ 60.4333(b)(1) § 60.4335(b)(1) § 60.4335(b)(2) § 60.4335(b)(3) [G]§ 60.4345 § 60.4350(a) § 60.4350(b) § 60.4350(c) § 60.4350(d) § 60.4350(e) § 60.4350(f) § 60.4350(f)(2) § 60.4350(h) [G]§ 60.4400(a) § 60.4400(b) § 60.4400(b)(1) § 60.4400(b)(2) § 60.4400(b)(4) § 60.4400(b)(5) § 60.4400(b)(6) [G]§ 60.4405	[G]§ 60.4345 § 60.4350(b)	[G]§ 60.4345 § 60.4350(d) § 60.4375(a) § 60.4380 [G]§ 60.4380(b) § 60.4395
B56P9GT96	EU	60KKKK-01	SO ₂	40 CFR Part 60, Subpart KKKK	§ 60.4330(a)(2) § 60.4333(a)	You must not burn in the subject stationary combustion turbine any fuel which contains total potential sulfur emissions in excess of 26 ng SO ₂ /J	§ 60.4365 § 60.4365(b) § 60.4415(a) § 60.4415(a)(1) § 60.4415(a)(1)(ii)	§ 60.4365(b)	§ 60.4375(a)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						(0.060 lb SO ₂ /MMBtu) heat input. If your turbine simultaneously fires multiple fuels, each fuel must meet this requirement.			
B56P9GT96	EU	63YYYY-01	112(B) HAPS	40 CFR Part 63, Subpart YYYY	§ 63.6095(d)	If you start up a new or reconstructed stationary combustion turbine that is a lean premix gas-fired stationary combustion turbine or diffusion flame gas-fired stationary combustion turbine as defined by this subpart, you must comply with the Initial Notification requirements set forth in §63.6145 but need not comply with any other requirement of this subpart until EPA takes final action to require compliance.	None	None	§ 63.6145(a) § 63.6145(b) § 63.6145(c) § 63.6145(d)
B56P9SB1	EU	R7ICI-01	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(1)(A) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.320(a) § 117.320(b) [G]§ 117.320(c) § 117.320(i) § 117.320(j) § 117.320(k) § 117.340(f)(1) § 117.340(l)(2) § 117.340(p)(1)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the	§ 117.320(d) [G]§ 117.320(e) § 117.320(h) § 117.320(k) [G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(1) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(c)(1) [G]§ 117.340(c)(3)	§ 117.320(f) § 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.320(g) § 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 117.340(p)(3)	alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.340(f)(2) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(i) § 117.8100(a)(1)(B)(iii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)		§ 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)
B56P9SB1	EU	R7ICI-01	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(A) § 117.310(c)(3) § 117.340(f)(1) § 117.8120	CO emissions must not exceed 400 ppmv at 3.0% O ₂ , dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(3) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(e) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(7) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(iii) § 117.8100(a)(1)(B)(iii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) § 117.8120(1) § 117.8120(1)(A)		§ 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)
B56P9SB1	EU	R7ICI-01	NH ₃	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(2) § 117.310(c)(2)(A)	For boilers that inject urea or ammonia into the exhaust stream for NO _x control, ammonia emissions must not exceed 10 ppmv at 3.0% O ₂ , dry.	§ 117.335(a)(2) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(b)(1) § 117.340(b)(3) § 117.340(d) § 117.8000(b) § 117.8000(c) § 117.8000(c)(3) § 117.8000(c)(4) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8130 § 117.8130(1)	§ 117.345(a) § 117.345(f) § 117.345(f)(11) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
B56P9SB1	EU	60Db-01	SO ₂	40 CFR Part 60, Subpart Db	§ 60.40b(a)	This subpart applies to each steam generating unit constructed, modified, or reconstructed after 6/19/84, and that has a heat input capacity from fuels combusted in the unit > 29 MW (100 MMBtu/hr).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)
B56P9SB1	EU	60Db-01	PM	40 CFR Part 60, Subpart Db	§ 60.40b(a)	This subpart applies to each steam generating unit constructed, modified, or reconstructed after 6/19/84, and that has a heat input capacity from fuels combusted in the unit > 29 MW (100 MMBtu/hr).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)
B56P9SB1	EU	60Db-01	PM (Opacity)	40 CFR Part 60, Subpart Db	§ 60.40b(a)	This subpart applies to each steam generating unit constructed, modified, or reconstructed after 6/19/84, and that has a heat input capacity from fuels combusted in the unit > 29 MW (100 MMBtu/hr).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)
B56P9SB1	EU	60Db-01	NO _x	40 CFR Part 60, Subpart Db	§ 60.44b(l)(1) § 60.44b(h) § 60.44b(i) § 60.46b(a)	Affected facilities combusting coal, oil, or natural gas, or a mixture of these fuels, or any other fuels: a limit of 86 ng/JI (0.20 lb/million Btu) heat input unless the affected facility meets the specified requirements.	§ 60.46b(c) § 60.46b(f) § 60.46b(f)(2) [G]§ 60.48b(b) § 60.48b(c) § 60.48b(d) § 60.48b(e) [G]§ 60.48b(e)(2) § 60.48b(e)(3) § 60.48b(f)	[G]§ 60.48b(b) § 60.48b(c) [G]§ 60.49b(d) [G]§ 60.49b(g) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3) § 60.49b(b)
B56P9SB1	EU	63DDDDDD-01	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7505 The permit holder shall comply with	The permit holder shall comply with the applicable requirements of 40 CFR	The permit holder shall comply with the applicable	The permit holder shall comply with the applicable	The permit holder shall comply with the applicable reporting

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart DDDDD	Part 63, Subpart DDDDD	monitoring and testing requirements of 40 CFR Part 63, Subpart DDDDD	recordkeeping requirements of 40 CFR Part 63, Subpart DDDDD	requirements of 40 CFR Part 63, Subpart DDDDD
B56P9SB2	EU	R7ICI-01	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(1)(A) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.320(a) § 117.320(b) [G]§ 117.320(c) § 117.320(i) § 117.320(j) § 117.320(k) § 117.340(f)(1) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	§ 117.320(d) [G]§ 117.320(e) § 117.320(h) § 117.320(k) [G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(1) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(c)(1) [G]§ 117.340(c)(3) [G]§ 117.340(f)(2) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(i) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3)	§ 117.320(f) § 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.320(g) § 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)		
B56P9SB2	EU	R7ICI-01	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(A) § 117.310(c)(3) § 117.340(f)(1) § 117.8120	CO emissions must not exceed 400 ppmv at 3.0% O ₂ , dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(3) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(e) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(B)(iii)) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(7) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) § 117.8120(1) § 117.8120(1)(A)		
B56P9SB2	EU	R7ICI-01	NH ₃	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(2) § 117.310(c)(2)(A)	For boilers that inject urea or ammonia into the exhaust stream for NO _x control, ammonia emissions must not exceed 10 ppmv at 3.0% O ₂ , dry.	§ 117.335(a)(2) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(b)(1) § 117.340(b)(3) § 117.340(d) § 117.8000(b) § 117.8000(c) § 117.8000(c)(3) § 117.8000(c)(4) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8130 § 117.8130(1)	§ 117.345(a) § 117.345(f) § 117.345(f)(11) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
B56P9SB2	EU	60Db-01	SO ₂	40 CFR Part 60, Subpart Db	§ 60.40b(a)	This subpart applies to each steam generating unit constructed, modified, or reconstructed after 6/19/84, and that has a heat input capacity from fuels combusted in the unit > 29 MW (100 MMBtu/hr).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)
B56P9SB2	EU	60Db-01	PM	40 CFR Part 60, Subpart Db	§ 60.40b(a)	This subpart applies to each steam generating unit constructed, modified, or reconstructed after 6/19/84, and that has a heat input capacity from fuels	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						combusted in the unit > 29 MW (100 MMBtu/hr).			
B56P9SB2	EU	60Db-01	PM (Opacity)	40 CFR Part 60, Subpart Db	§ 60.40b(a)	This subpart applies to each steam generating unit constructed, modified, or reconstructed after 6/19/84, and that has a heat input capacity from fuels combusted in the unit > 29 MW (100 MMBtu/hr).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)
B56P9SB2	EU	60Db-01	NO _x	40 CFR Part 60, Subpart Db	§ 60.44b(l)(1) § 60.44b(h) § 60.44b(i) § 60.46b(a)	Affected facilities combusting coal, oil, or natural gas, or a mixture of these fuels, or any other fuels: a limit of 86 ng/Jl (0.20 lb/million Btu) heat input unless the affected facility meets the specified requirements.	§ 60.46b(c) § 60.46b(f) § 60.46b(f)(2) [G]§ 60.48b(b) § 60.48b(c) § 60.48b(d) § 60.48b(e) [G]§ 60.48b(e)(2) § 60.48b(e)(3) § 60.48b(f)	[G]§ 60.48b(b) § 60.48b(c) [G]§ 60.49b(d) [G]§ 60.49b(g) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3) § 60.49b(b)
B56P9SB2	EU	63DDDDDD-01	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7505 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart DDDDD
B56P9SB3	EU	R7ICI-01	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(1)(A) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass	§ 117.320(d) [G]§ 117.320(e) § 117.320(h) § 117.320(k) [G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b)	§ 117.320(f) § 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) [G]§ 117.345(f)(8) § 117.345(f)(9)	§ 117.320(g) § 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 117.310(e)(4) § 117.320(a) § 117.320(b) [G]§ 117.320(c) § 117.320(i) § 117.320(j) § 117.320(k) § 117.340(f)(1) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	§ 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(1) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(c)(1) [G]§ 117.340(c)(3) [G]§ 117.340(f)(2) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(i) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)	§ 117.8100(a)(5)(C)	§ 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)
B56P9SB3	EU	R7ICI-01	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(A) § 117.310(c)(3) § 117.340(f)(1) § 117.8120	CO emissions must not exceed 400 ppmv at 3.0% O ₂ , dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(7)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.335(f) § 117.335(f)(3) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(e) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(iii) § 117.8100(a)(1)(B)(iii)) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) § 117.8120(1) § 117.8120(1)(A)	§ 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)
B56P9SB3	EU	R7ICI-01	NH ₃	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(2) § 117.310(c)(2)(A)	For boilers that inject urea or ammonia into the exhaust stream for NO _x control, ammonia emissions must not exceed 10 ppmv at 3.0% O ₂ , dry.	§ 117.335(a)(2) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(b)(1) § 117.340(b)(3)	§ 117.345(a) § 117.345(f) § 117.345(f)(11) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.340(d) § 117.8000(b) § 117.8000(c) § 117.8000(c)(3) § 117.8000(c)(4) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8130 § 117.8130(1)		§ 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
B56P9SB3	EU	60Db-01	SO ₂	40 CFR Part 60, Subpart Db	§ 60.40b(a)	This subpart applies to each steam generating unit constructed, modified, or reconstructed after 6/19/84, and that has a heat input capacity from fuels combusted in the unit > 29 MW (100 MMBtu/hr).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)
B56P9SB3	EU	60Db-01	PM	40 CFR Part 60, Subpart Db	§ 60.40b(a)	This subpart applies to each steam generating unit constructed, modified, or reconstructed after 6/19/84, and that has a heat input capacity from fuels combusted in the unit > 29 MW (100 MMBtu/hr).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)
B56P9SB3	EU	60Db-01	PM (Opacity)	40 CFR Part 60, Subpart Db	§ 60.40b(a)	This subpart applies to each steam generating unit constructed, modified, or reconstructed after 6/19/84, and that has a heat input capacity from fuels combusted in the unit > 29 MW (100 MMBtu/hr).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)
B56P9SB3	EU	60Db-01	NO _x	40 CFR Part 60, Subpart Db	§ 60.44b(l)(1) § 60.44b(h) § 60.44b(i)	Affected facilities combusting coal, oil, or natural gas, or a mixture of	§ 60.46b(c) § 60.46b(f) § 60.46b(f)(2)	[G]§ 60.48b(b) § 60.48b(c) [G]§ 60.49b(d)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.46b(a)	these fuels, or any other fuels: a limit of 86 ng/Jl (0.20 lb/million Btu) heat input unless the affected facility meets the specified requirements.	[G]§ 60.48b(b) § 60.48b(c) § 60.48b(d) § 60.48b(e) [G]§ 60.48b(e)(2) § 60.48b(e)(3) § 60.48b(f)	[G]§ 60.49b(g) § 60.49b(o)	§ 60.49b(b)
B56P9SB3	EU	63DDDDD-01	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7505 The permit holder shall comply with the applicable limitation, standard and/or equipment specification requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart DDDDD
B56P9SB4	EU	R7ICI-01	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(1)(A) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.320(a) § 117.320(b) [G]§ 117.320(c) § 117.320(i) § 117.320(j) § 117.320(k) § 117.340(f)(1) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	§ 117.320(d) [G]§ 117.320(e) § 117.320(h) § 117.320(k) [G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(1) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(c)(1) [G]§ 117.340(c)(3) [G]§ 117.340(f)(2) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1)	§ 117.320(f) § 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.320(g) § 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(i) § 117.8100(a)(1)(B)(ii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)		
B56P9SB4	EU	R7ICI-01	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(A) § 117.310(c)(3) § 117.340(f)(1) § 117.8120	CO emissions must not exceed 400 ppmv at 3.0% O ₂ , dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(3) § 117.335(g) § 117.340(a) § 117.340(b)(1) § 117.340(b)(3) § 117.340(e) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(ii)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(7) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.8100(a)(1)(B)(iii)) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) § 117.8120(1) § 117.8120(1)(A)		[G]§ 117.8010(8) § 117.8100(c)
B56P9SB4	EU	R7ICI-01	NH ₃	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(2) § 117.310(c)(2)(A)	For boilers that inject urea or ammonia into the exhaust stream for NO _x control, ammonia emissions must not exceed 10 ppmv at 3.0% O ₂ , dry.	§ 117.335(a)(2) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(b)(1) § 117.340(b)(3) § 117.340(d) § 117.8000(b) § 117.8000(c) § 117.8000(c)(3) § 117.8000(c)(4) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8130 § 117.8130(1)	§ 117.345(a) § 117.345(f) § 117.345(f)(11) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
B56P9SB4	EU	60Db-01	SO ₂	40 CFR Part 60, Subpart Db	§ 60.40b(a)	This subpart applies to each steam generating unit constructed, modified, or	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						reconstructed after 6/19/84, and that has a heat input capacity from fuels combusted in the unit > 29 MW (100 MMBtu/hr).			
B56P9SB4	EU	60Db-01	PM	40 CFR Part 60, Subpart Db	§ 60.40b(a)	This subpart applies to each steam generating unit constructed, modified, or reconstructed after 6/19/84, and that has a heat input capacity from fuels combusted in the unit > 29 MW (100 MMBtu/hr).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)
B56P9SB4	EU	60Db-01	PM (Opacity)	40 CFR Part 60, Subpart Db	§ 60.40b(a)	This subpart applies to each steam generating unit constructed, modified, or reconstructed after 6/19/84, and that has a heat input capacity from fuels combusted in the unit > 29 MW (100 MMBtu/hr).	None	[G]§ 60.49b(d) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3)
B56P9SB4	EU	60Db-01	NO _x	40 CFR Part 60, Subpart Db	§ 60.44b(l)(1) § 60.44b(h) § 60.44b(i) § 60.46b(a)	Affected facilities combusting coal, oil, or natural gas, or a mixture of these fuels, or any other fuels: a limit of 86 ng/Jl (0.20 lb/million Btu) heat input unless the affected facility meets the specified requirements.	§ 60.46b(c) § 60.46b(f) § 60.46b(f)(2) [G]§ 60.48b(b) § 60.48b(c) § 60.48b(d) § 60.48b(e) [G]§ 60.48b(e)(2) § 60.48b(e)(3) § 60.48b(f)	[G]§ 60.48b(b) § 60.48b(c) [G]§ 60.49b(d) [G]§ 60.49b(g) § 60.49b(o)	§ 60.49b(a) § 60.49b(a)(1) § 60.49b(a)(3) § 60.49b(b)
B56P9SB4	EU	63DDDDD-01	112(B) HAPS	40 CFR Part 63, Subpart DDDDD	§ 63.7505 The permit holder shall comply with the applicable limitation, standard and/or equipment	The permit holder shall comply with the applicable requirements of 40 CFR Part 63, Subpart DDDDD	The permit holder shall comply with the applicable monitoring and testing requirements of 40 CFR Part 63,	The permit holder shall comply with the applicable recordkeeping requirements of 40 CFR Part 63, Subpart	The permit holder shall comply with the applicable reporting requirements of 40 CFR Part 63, Subpart DDDDD

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					specification requirements of 40 CFR Part 63, Subpart DDDDD		Subpart DDDDD	DDDDD	
B56SB1	EP	R1111-01	PM (Opacity)	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(C) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 15% averaged over a six minute period for any source with a total flow rate of at least 100,000 acfm unless a CEMS is installed.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
B56SB1	EP	R5720-01	Highly Reactive VOC	30 TAC Chapter 115, HRVOC Vent Gas	§ 115.727(c)(2)	A vent gas stream that has the potential to emit HRVOCs, but has a concentration less than 100 ppmv at all times or has a maximum potential flow rate equal to or less than 100 dry standard cubic feet per hour is exempt from this division with the exception of § 115.726(e)(3)(A) of this title. The maximum potential HRVOC emissions for the sum of all vent gas streams claimed under this exemption, must be less for the account specified in § 115.722(a) or (b) of this title than 0.5 tpy.	None	§ 115.726(e)(3)(A) § 115.726(j)(2)	None
B56SB2	EP	R1111-01	PM (Opacity)	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(C) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 15% averaged over a six minute period for any source with a total flow rate of at least 100,000 acfm unless a	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						CEMS is installed.			
B56SB2	EP	R5720-01	Highly Reactive VOC	30 TAC Chapter 115, HRVOC Vent Gas	§ 115.727(c)(2)	A vent gas stream that has the potential to emit HRVOCs, but has a concentration less than 100 ppmv at all times or has a maximum potential flow rate equal to or less than 100 dry standard cubic feet per hour is exempt from this division with the exception of § 115.726(e)(3)(A) of this title. The maximum potential HRVOC emissions for the sum of all vent gas streams claimed under this exemption, must be less for the account specified in § 115.722(a) or (b) of this title than 0.5 tpy.	None	§ 115.726(e)(3)(A) § 115.726(j)(2)	None
B56SB3	EP	R1111-01	PM (Opacity)	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(C) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 15% averaged over a six minute period for any source with a total flow rate of at least 100,000 acfm unless a CEMS is installed.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
B56SB3	EP	R5720-01	Highly Reactive VOC	30 TAC Chapter 115, HRVOC Vent Gas	§ 115.727(c)(2)	A vent gas stream that has the potential to emit HRVOCs, but has a concentration less than 100 ppmv at all times or has a maximum potential flow rate equal to or less than 100 dry standard cubic feet per hour is exempt from this division with the exception of §	None	§ 115.726(e)(3)(A) § 115.726(j)(2)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						115.726(e)(3)(A) of this title. The maximum potential HRVOC emissions for the sum of all vent gas streams claimed under this exemption, must be less for the account specified in § 115.722(a) or (b) of this title than 0.5 tpy.			
B56SB4	EP	R1111-01	PM (Opacity)	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(C) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 15% averaged over a six minute period for any source with a total flow rate of at least 100,000 acfm unless a CEMS is installed.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
B56SB4	EP	R5720-01	Highly Reactive VOC	30 TAC Chapter 115, HRVOC Vent Gas	§ 115.727(c)(2)	A vent gas stream that has the potential to emit HRVOCs, but has a concentration less than 100 ppmv at all times or has a maximum potential flow rate equal to or less than 100 dry standard cubic feet per hour is exempt from this division with the exception of § 115.726(e)(3)(A) of this title. The maximum potential HRVOC emissions for the sum of all vent gas streams claimed under this exemption, must be less for the account specified in § 115.722(a) or (b) of this title than 0.5 tpy.	None	§ 115.726(e)(3)(A) § 115.726(j)(2)	None
B56SEP001	EU	R5131-01	VOC	30 TAC Chapter 115, Water	§ 115.137(a)(2) [G]§ 115.132(a)(4)	Any single or multiple compartment VOC water	[G]§ 115.135(a) § 115.136(a)(1)	§ 115.136(a)(1) § 115.136(a)(3)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
				Separation		separator which separates materials having a true vapor pressure of VOC < .5 psia obtained from any equipment is exempt from §115.132(a).	§ 115.136(a)(3) § 115.136(a)(4)	§ 115.136(a)(4)	
B56ST190	EU	61FF-01	Benzene	40 CFR Part 61, Subpart FF	§ 61.343(b)(2) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(b)(3) § 61.343(c) § 61.343(d)	The owner/operator shall install, operate, and maintain a fixed roof as specified in §61.343(a)(1)(i).	§ 61.343(a)(1)(i)(A) § 61.343(c)	§ 61.356(d) § 61.356(g)	None
B56ST290	EU	61FF-01	Benzene	40 CFR Part 61, Subpart FF	§ 61.343(b)(2) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(b)(3) § 61.343(c) § 61.343(d)	The owner/operator shall install, operate, and maintain a fixed roof as specified in §61.343(a)(1)(i).	§ 61.343(a)(1)(i)(A) § 61.343(c)	§ 61.356(d) § 61.356(g)	None
B56TL001	EU	R5211-01	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.213(b) § 115.212(a)(3)(B) § 115.212(a)(3)(E) § 115.213(b)(1) § 115.213(b)(4) [G]§ 115.213(b)(6) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(ii)	General loading - 90% overall control option in the covered non-attainment counties. As an alternative operations may elect to achieve a 90% overall control of emissions at the account.	§ 115.212(a)(3)(B) § 115.213(b) § 115.213(b)(1) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) § 115.215(4) § 115.215(9)	§ 115.213(b)(1) § 115.216 § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	§ 115.213(b)(1) § 115.213(b)(2) § 115.213(b)(3) § 115.213(b)(4)
B664PSP4A	EU	R5131-01	VOC	30 TAC Chapter 115, Water Separation	§ 115.137(a)(2) [G]§ 115.132(a)(4)	Any single or multiple compartment VOC water separator which separates materials having a true vapor pressure of VOC < .5 psia obtained from any equipment is exempt from §115.132(a).	[G]§ 115.135(a) § 115.136(a)(1) § 115.136(a)(3) § 115.136(a)(4)	§ 115.136(a)(1) § 115.136(a)(3) § 115.136(a)(4)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
B664PSP4B	EU	R5131-01	VOC	30 TAC Chapter 115, Water Separation	§ 115.137(a)(2) [G]§ 115.132(a)(4)	Any single or multiple compartment VOC water separator which separates materials having a true vapor pressure of VOC < .5 psia obtained from any equipment is exempt from §115.132(a).	[G]§ 115.135(a) § 115.136(a)(1) § 115.136(a)(3) § 115.136(a)(4)	§ 115.136(a)(1) § 115.136(a)(3) § 115.136(a)(4)	None
BM54SILR30	EU	R5211-01	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.213(b) § 115.212(a)(3)(B) § 115.212(a)(3)(E) § 115.213(b)(1) § 115.213(b)(4) [G]§ 115.213(b)(6) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(ii)	General loading - 90% overall control option in the covered non-attainment counties. As an alternative operations may elect to achieve a 90% overall control of emissions at the account.	§ 115.212(a)(3)(B) § 115.213(b) § 115.213(b)(1) § 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(1) § 115.215(10) [G]§ 115.215(2) § 115.215(4) § 115.215(9)	§ 115.213(b)(1) § 115.216 § 115.216(2) § 115.216(3)(A) § 115.216(3)(A)(i) § 115.216(3)(A)(ii) § 115.216(3)(A)(iii) § 115.216(3)(B)	§ 115.213(b)(1) § 115.213(b)(2) § 115.213(b)(3) § 115.213(b)(4)
BM54SIST30	EU	R5112-01	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
BM54SIST30	EU	61FF-01	Benzene	40 CFR Part 61, Subpart FF	§ 61.343(b)(2) § 61.343(a)(1)(i)(A) § 61.343(a)(1)(i)(B) § 61.343(b)(3) § 61.343(c) § 61.343(d)	The owner/operator shall install, operate, and maintain a fixed roof as specified in §61.343(a)(1)(i).	§ 61.343(a)(1)(i)(A) § 61.343(c)	§ 61.356(d) § 61.356(g)	None
BP4ST4003	EU	R5112-01	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
PROPWRA	PRO	R5460-01	VOC	30 TAC Chapter 115, Subchapter E, Division 6	§ 115.463(a)(1) [G]§ 115.463(c)	The owner or operator shall limit the volatile organic compounds (VOC) content of cleaning solutions to 0.42 pound of VOC per gallon of solution (lb VOC/gal solution), as applied.	[G]§ 115.465(1)	§ 115.468(b)(1) § 115.468(b)(4) § 115.468(b)(5)	None
PROPWRA	PRO	R5460-02	VOC	30 TAC Chapter 115, Subchapter E, Division 6	§ 115.463(a)(2) [G]§ 115.463(c)	The owner or operator shall limit the composite partial vapor pressure of the cleaning solution to 8.0 millimeters of mercury at 20 degrees Celsius (68 degrees Fahrenheit).	[G]§ 115.465(1)	§ 115.468(b)(1) § 115.468(b)(4) § 115.468(b)(5)	None
PROPWRB	PRO	R5460-01	VOC	30 TAC Chapter 115, Subchapter E, Division 6	§ 115.463(a)(1) [G]§ 115.463(c)	The owner or operator shall limit the volatile organic compounds (VOC) content of cleaning solutions to 0.42 pound of VOC per gallon of solution (lb VOC/gal solution), as applied.	[G]§ 115.465(1)	§ 115.468(b)(1) § 115.468(b)(4) § 115.468(b)(5)	None
PROPWRB	PRO	R5460-02	VOC	30 TAC Chapter 115, Subchapter E, Division 6	§ 115.463(a)(2) [G]§ 115.463(c)	The owner or operator shall limit the composite partial vapor pressure of the cleaning solution to 8.0 millimeters of mercury at 20 degrees Celsius (68 degrees Fahrenheit).	[G]§ 115.465(1)	§ 115.468(b)(1) § 115.468(b)(4) § 115.468(b)(5)	None
PROPWRO C	PRO	R5460-01	VOC	30 TAC Chapter 115, Subchapter E, Division 6	§ 115.463(a)(1) [G]§ 115.463(c)	The owner or operator shall limit the volatile organic compounds (VOC) content of cleaning solutions to 0.42 pound of VOC per gallon of solution (lb VOC/gal solution), as applied.	[G]§ 115.465(1)	§ 115.468(b)(1) § 115.468(b)(4) § 115.468(b)(5)	None
PROPWRO	PRO	R5460-02	VOC	30 TAC Chapter	§ 115.463(a)(2)	The owner or operator shall	[G]§ 115.465(1)	§ 115.468(b)(1)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
C				115, Subchapter E, Division 6	[G]§ 115.463(c)	limit the composite partial vapor pressure of the cleaning solution to 8.0 millimeters of mercury at 20 degrees Celsius (68 degrees Fahrenheit).		§ 115.468(b)(4) § 115.468(b)(5)	

Additional Monitoring Requirements

Periodic Monitoring Summary 53

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: B106PSC1	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Degreasing Processes	SOP Index No.: R5412-01
Pollutant: VOC	Main Standard: § 115.412(1)
Monitoring Information	
Indicator: Visual Inspection	
Minimum Frequency: Monthly	
Averaging Period: n/a	
Deviation Limit: Any monitoring data collected which indicates that the cold cleaner is not in compliance with the applicable requirements of §115.412(1)(A)-(F) shall be considered and reported as a deviation.	
Periodic Monitoring Text: Inspect equipment and record data monthly to ensure compliance with any applicable requirements in § 115.412(1)(A)-(F). Any monitoring data which indicates that the cold cleaner is not in compliance with the applicable requirements of § 115.412(1)(A)-(F) shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: B246PSC412	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 115, Degreasing Processes	SOP Index No.: R5412-01
Pollutant: VOC	Main Standard: § 115.412(1)
Monitoring Information	
Indicator: Visual Inspection	
Minimum Frequency: Monthly	
Averaging Period: n/a	
Deviation Limit: Any monitoring data collected which indicates that the cold cleaner is not in compliance with the applicable requirements of §115.412(1)(A)-(F) shall be considered and reported as a deviation.	
Periodic Monitoring Text: Inspect equipment and record data monthly to ensure compliance with any applicable requirements in § 115.412(1)(A)-(F). Any monitoring data which indicates that the cold cleaner is not in compliance with the applicable requirements of § 115.412(1)(A)-(F) shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: B56CR96	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-01
Pollutant: PM (Opacity)	Main Standard: § 111.111(a)(1)(C)
Monitoring Information	
Indicator: Fuel Type	
Minimum Frequency: Annually	
Averaging Period: n/a	
Deviation Limit: Use of an unauthorized fuel	
Periodic Monitoring Text: Record the type of fuel used by the unit. If an alternate fuel is fired, either alone or in combination with the specified gas, it shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: B56SB1	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-01
Pollutant: PM (Opacity)	Main Standard: § 111.111(a)(1)(C)
Monitoring Information	
Indicator: Fuel Type	
Minimum Frequency: Annually	
Averaging Period: n/a	
Deviation Limit: Use of an unauthorized fuel	
Periodic Monitoring Text: Record the type of fuel used by the unit. If an alternate fuel is fired, either alone or in combination with the specified gas, it shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: B56SB2	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-01
Pollutant: PM (Opacity)	Main Standard: § 111.111(a)(1)(C)
Monitoring Information	
Indicator: Fuel Type	
Minimum Frequency: Annually	
Averaging Period: n/a	
Deviation Limit: Use of an unauthorized fuel.	
Periodic Monitoring Text: Record the type of fuel used by the unit. If an alternate fuel is fired, either alone or in combination with the specified gas, it shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: B56SB3	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-01
Pollutant: PM (Opacity)	Main Standard: § 111.111(a)(1)(C)
Monitoring Information	
Indicator: Fuel Type	
Minimum Frequency: Annually	
Averaging Period: n/a	
Deviation Limit: Use of an unauthorized fuel.	
Periodic Monitoring Text: Record the type of fuel used by the unit. If an alternate fuel is fired, either alone or in combination with the specified gas, it shall be considered and reported as a deviation.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: B56SB4	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111-01
Pollutant: PM (Opacity)	Main Standard: § 111.111(a)(1)(C)
Monitoring Information	
Indicator: Fuel Type	
Minimum Frequency: Annually	
Averaging Period: n/a	
Deviation Limit: Use of an unauthorized fuel.	
Periodic Monitoring Text: Record the type of fuel used by the unit. If an alternate fuel is fired, either alone or in combination with the specified gas, it shall be considered and reported as a deviation.	

Permit Shield

Permit Shield 61

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
A153PSP39	N/A	40 CFR Part 61, Subpart FF	Does not contain or store benzene waste.
A153PSP39	N/A	40 CFR Part 63, Subpart VV	Not referenced by another 40 CFR 60, 61, or 63.
A25SIFU01	N/A	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	The unit does not contain a synthetic organic chemical, polymer, resin, or methyl-tert-butylether manufacturing process, natural gas/gasoline processing, or a petroleum refinery.
A25SIFU01	N/A	40 CFR Part 61, Subpart F	The unit does not produce ethylene dichloride, vinyl chloride, or polymers containing polymerized vinyl chloride.
B4SIFU01	N/A	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	The unit does not contain a synthetic organic chemical, polymer, resin, or methyl-tert-butylether manufacturing process, natural gas/gasoline processing, or a petroleum refinery.
B4SIFU01	N/A	40 CFR Part 61, Subpart F	The unit does not produce ethylene dichloride, vinyl chloride, or polymers containing polymerized vinyl chloride.
B56CR96	N/A	40 CFR Part 61, Subpart F	The unit is not in an application area that produces ethylene dichloride, vinyl chloride, or polymers containing polymerized vinyl chloride.
B56P9FU01	N/A	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	The unit does not contain a synthetic organic chemical, polymer, resin, or methyl-tert-butylether manufacturing process, natural gas/gasoline processing, or a petroleum refinery.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
B56P9FU01	N/A	40 CFR Part 61, Subpart F	The unit is not in an application area that produces ethylene dichloride, vinyl chloride, or polymers containing polymerized vinyl chloride.
B56SEP001	N/A	40 CFR Part 61, Subpart F	The unit is not in an application area that produces ethylene dichloride, vinyl chloride, or polymers containing polymerized vinyl chloride.
B56ST190	N/A	40 CFR Part 60, Subpart Kb	Exempt since tank capacity is less than 75 cubic meters (19,800 gallons).
B56ST190	N/A	40 CFR Part 61, Subpart F	The unit is not in an application area that produces ethylene dichloride, vinyl chloride, or polymers containing polymerized vinyl chloride.
B56ST290	N/A	40 CFR Part 60, Subpart Kb	Exempt since tank capacity is < 75 cubic meters (19,800 gallons).
B56ST290	N/A	40 CFR Part 61, Subpart F	The unit is not in an application area that produces ethylene dichloride, vinyl chloride, or polymers containing polymerized vinyl chloride.
B56TL001	N/A	40 CFR Part 61, Subpart F	The unit is not in an application area that produces ethylene dichloride, vinyl chloride, or polymers containing polymerized vinyl chloride.
B664PSP4A	N/A	40 CFR Part 61, Subpart FF	Does not contain or store benzene waste.
B664PSP4A	N/A	40 CFR Part 63, Subpart VV	Not referenced by another 40 CFR 60, 61, or 63.
B664PSP4B	N/A	40 CFR Part 61, Subpart FF	Does not contain or store benzene waste.
B664PSP4B	N/A	40 CFR Part 63, Subpart VV	Not referenced by another 40 CFR 60, 61, or 63.

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
BM54SIFU01	N/A	30 TAC Chapter 115, Pet. Refinery & Petrochemicals	The unit does not contain a synthetic organic chemical, polymer, resin, or methyl-tert-butylether manufacturing process, natural gas/gasoline processing, or a petroleum refinery.
BM54SIFU01	N/A	40 CFR Part 61, Subpart F	The unit does not produce ethylene dichloride, vinyl chloride, or polymers containing polymerized vinyl chloride.

New Source Review Authorization References

New Source Review Authorization References	65
New Source Review Authorization References by Emission Unit	66

New Source Review Authorization References

The New Source Review authorizations listed in the table below are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Prevention of Significant Deterioration (PSD) Permits	
PSD Permit No.: PSDTX986	Issuance Date: 01/31/2017
Nonattainment (NA) Permits	
NA Permit No.: N059	Issuance Date: 01/31/2017
Title 30 TAC Chapter 116 Permits, Special Permits, and Other Authorizations (Other Than Permits By Rule, PSD Permits, or NA Permits) for the Application Area.	
Authorization No.: 46306	Issuance Date: 01/31/2017
Authorization No.: 83846	Issuance Date: 06/16/2016
Permits By Rule (30 TAC Chapter 106) for the Application Area	
Number: 106.263	Version No./Date: 11/01/2001
Number: 106.371	Version No./Date: 09/04/2000
Number: 106.454	Version No./Date: 11/01/2001
Number: 106.472	Version No./Date: 09/04/2000
Number: 106.473	Version No./Date: 09/04/2000
Number: 106.477	Version No./Date: 09/04/2000
Number: 106.478	Version No./Date: 09/04/2000
Number: 106.532	Version No./Date: 09/04/2000

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
A153P3STLO	GT-37 LUBE OIL STORAGE TANK A-1501	106.478/09/04/2000
A153PSP39	OIL/WATER SEPARATOR (T39)	106.478/09/04/2000
A25SIFU01	A-2500 DISTILLATE TANK FUGITIVES	106.478/09/04/2000
A25SILRT25	A-25 - DISTILLATE LOADING	106.473/09/04/2000
A25SISTT25	A-2500 DISTILLATE TANK T-25	106.478/09/04/2000
B106PSC1	B-1011 DEGREASER	106.454/11/01/2001
B246PSC412	B-2412 DEGREASER	106.454/11/01/2001
B4SIFU01	B-400 DISTILLATE TANK FUGITIVES	106.478/09/04/2000
B4SILRD500	B-400 DISTILLATE LOADING	106.473/09/04/2000
B4SISTD500	B-400 DISTILLATE TANK D-500	106.478/09/04/2000
B56CR96	GT-96 TURBINE/DB-96 DUCT BURNER STACK	46306, 83846, N059, PSDTX986
B56P9DB96	DB-96 DUCT BURNER	46306, 83846, N059, PSDTX986
B56P9FU01	PIPING FUGITIVES	46306, N059, PSDTX986
B56P9GT96	GT-96 TURBINE	46306, 83846, N059, PSDTX986
B56P9SB1	POWER 9 STEAM BOILER FB-91	46306, 83846, N059, PSDTX986
B56P9SB2	POWER 9 STEAM BOILER FB-92	46306, 83846, N059, PSDTX986
B56P9SB3	POWER 9 STEAM BOILER FB-93	46306, 83846, N059, PSDTX986
B56P9SB4	POWER 9 STEAM BOILER FB-94	46306, 83846, N059, PSDTX986
B56SB1	POWER 9 STEAM BOILER FB-91 VENT	46306, 83846, N059, PSDTX986
B56SB2	POWER 9 STEAM BOILER FB-92 VENT	46306, 83846, N059, PSDTX986
B56SB3	POWER 9 STEAM BOILER FB-93 VENT	46306, 83846, N059, PSDTX986

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
B56SB4	POWER 9 STEAM BOILER FB-94 VENT	46306, 83846, N059, PSDTX986
B56SEP001	OIL-WATER SEPARATOR	106.532/09/04/2000
B56ST190	DISTILLATE STORAGE TANK	46306, N059, PSDTX986
B56ST290	DISTILLATE STORAGE TANK	46306, N059, PSDTX986
B56TL001	DISTILLATE TANK LOADING	46306, N059, PSDTX986
B664PSP4A	OIL/WATER SEPARATOR 4A	106.478/09/04/2000
B664PSP4B	OIL/WATER SEPARATOR 4B	106.478/09/04/2000
BM54SIFU01	A/B METER STATION DISTILLATE TANK FUGITIVES.	106.478/09/04/2000
BM54SILR30	A/B METER STATION DISTILLATE LOADING	106.473/09/04/2000
BM54SIST30	A/B METER STATION DISTILLATE TANK D-301	106.478/09/04/2000
BP4ST4003	LUBE OIL STORAGE TANK D-4003	106.478/09/04/2000
PROPWRA	POWER PROCESS UNITS PLANT A	106.263/11/01/2001
PROPWRB	POWER PROCESS UNITS PLANT B	106.263/11/01/2001
PROPWROC	POWER PROCESS UNITS OYSTER CREEK	106.263/11/01/2001

Appendix A

Acronym List 69

Acronym List

The following abbreviations or acronyms may be used in this permit:

ACFM	actual cubic feet per minute
AMOC	alternate means of control
ARP	Acid Rain Program
ASTM	American Society of Testing and Materials
B/PA	Beaumont/Port Arthur (nonattainment area)
CAM	Compliance Assurance Monitoring
CD	control device
CEMS	continuous emissions monitoring system
CFR	Code of Federal Regulations
COMS	continuous opacity monitoring system
CVS	closed vent system
D/FW	Dallas/Fort Worth (nonattainment area)
EP	emission point
EPA	U.S. Environmental Protection Agency
EU	emission unit
FCAA Amendments	Federal Clean Air Act Amendments
FOP	federal operating permit
gr/100 scf	grains per 100 standard cubic feet
HAP	hazardous air pollutant
H/G/B	Houston/Galveston/Brazoria (nonattainment area)
H ₂ S	hydrogen sulfide
ID No.	identification number
lb/hr	pound(s) per hour
MACT	Maximum Achievable Control Technology (40 CFR Part 63)
MMBtu/hr	Million British thermal units per hour
NA	nonattainment
N/A	not applicable
NADB	National Allowance Data Base
NESHAP	National Emission Standards for Hazardous Air Pollutants (40 CFR Part 61)
NO _x	nitrogen oxides
NSPS	New Source Performance Standard (40 CFR Part 60)
NSR	New Source Review
ORIS	Office of Regulatory Information Systems
Pb	lead
PBR	Permit By Rule
PEMS	predictive emissions monitoring system
PM	particulate matter
ppmv	parts per million by volume
PRO	process unit
PSD	prevention of significant deterioration
psia	pounds per square inch absolute
SIP	state implementation plan
SO ₂	sulfur dioxide
TCEQ	Texas Commission on Environmental Quality
TSP	total suspended particulate
TVP	true vapor pressure
U.S.C.	United States Code
VOC	volatile organic compound

Appendix B

Major NSR Summary Table 71

Major NSR Summary Table

Permit Number: 46306, PSDTX986, and N059					Issuance Date: 1/31/2017		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lb/hour	TPY (4)	Spec. Cond.	Spec. Cond.	Spec. Cond.
B56SB1	FB-91 (550 MMBtu/hr Boiler)	NO _x	5.50	---	7, 12, 14, 17, 19	12, 14, 17, 19, 22, 23	12, 14, 17, 24, 25
		CO	20.05	---	7, 13, 14, 17, 19	13, 14, 17, 19, 22, 23	13, 14, 17, 25
		VOC	2.97	---	13, 19	19, 22, 23	
		SO ₂	7.79	---	12, 19	12, 19, 22, 23	12, 24
		PM ₁₀	9.44	---	6, 12, 13, 14, 19	6, 12, 13, 14, 19, 22, 23	12, 13, 14, 24
		NH ₃	2.44	---	7, 19, 21	19, 21, 22, 23	21
		H ₂ SO ₄	1.19	---	19	19, 22, 23	
		HCl (6)	11.72	---	13, 19	13, 19, 22, 23	13
		Hg	0.01	---	13, 19	13, 19, 22, 23	13
		Pb	0.01	---	19	19, 22, 23	13
B56SB2	FB-92 (550 MMBtu/hr Boiler)	NO _x	5.50	---	7, 12, 14, 17, 19	12, 14, 17, 19, 22, 23	12, 14, 17, 24, 25
		CO	20.05	---	7, 13, 14, 17, 19	13, 14, 17, 19, 22, 23	13, 14, 17, 25
		VOC	2.97	---	13, 19	19, 22, 23	
		SO ₂	7.79	---	12, 19	12, 19, 22, 23	12, 24
		PM ₁₀	9.44	---	6, 12, 13, 14, 19	6, 12, 13, 14, 19, 22, 23	12, 13, 14, 24
		NH ₃	2.44	---	7, 19, 21	19, 21, 22, 23	21
		H ₂ SO ₄	1.19	---	19	19, 22, 23	
		HCl (6)	11.72	---	13, 19	13, 19, 22, 23	13
		Hg	0.01	---	13, 19	13, 19, 22, 23	13
		Pb	0.01	---	19	19, 22, 23	13
B56SB3	FB-93 (550 MMBtu/hr Boiler)	NO _x	5.50	---	7, 12, 14, 17, 19	12, 14, 17, 19, 22, 23	12, 14, 17, 24, 25
		CO	20.05	---	7, 13, 14, 17, 19	13, 14, 17, 19, 22, 23	13, 14, 17, 25
		VOC	2.97	---	13, 19	19, 22, 23	
		SO ₂	7.79	---	12, 19	12, 19, 22, 23	12, 24
		PM ₁₀	9.44	---	6, 12, 13, 14, 19	6, 12, 13, 14, 19, 22, 23	12, 13, 14, 24
		NH ₃	2.44	---	7, 19, 21	19, 21, 22, 23	21
		H ₂ SO ₄	1.19	---	19	19, 22, 23	
		HCl (6)	11.72	---	13, 19	13, 19, 22, 23	13

Major NSR Summary Table

Permit Number: 46306, PSDTX986, and N059					Issuance Date: 1/31/2017		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lb/hour	TPY (4)	Spec. Cond.	Spec. Cond.	Spec. Cond.
		Hg	0.01	---	13, 19	13, 19, 22, 23	13
		Pb	0.01	---	19	19, 22, 23	13
B56SB4	FB-94 (550 MMBtu/hr Boiler)	NO _x	5.50	---	7, 12, 14, 17, 19	12, 14, 17, 19, 22, 23	12, 14, 17, 24, 25
		CO	20.05	---	7, 13, 14, 17, 19	13, 14, 17, 19, 22, 23	13, 14, 17, 25
		VOC	2.97	---	13, 19	19, 22, 23	
		SO ₂	7.79	---	12, 19	12, 19, 22, 23	12, 24
		PM ₁₀	9.44	---	6, 12, 13, 14, 19	6, 12, 13, 14, 19, 22, 23	12, 13, 14, 24
		NH ₃	2.44	---	7, 19, 21	19, 21, 22, 23	21
		H ₂ SO ₄	1.19	---	19	19, 22, 23	
		HCl (6)	11.72	---	13, 19	13, 19, 22, 23	13
		Hg	0.01	---	13, 19	13, 19, 22, 23	13
		Pb	0.01	---	19	19, 22, 23	13
B56SB1, BP9SB2, B56SB3, & B56SB4	FB-91, 92, 93, and 94	NO _x	---	66.93	7, 12, 14, 17, 19	12, 14, 17, 19, 22, 23	12, 14, 17, 24, 25
		CO	---	244.29	7, 13, 14, 17, 19	13, 14, 17, 19, 22, 23	13, 14, 17, 25
		VOC	---	36.14	13, 19	19, 22, 23	
		SO ₂	---	4.74	12, 19	12, 19, 22, 23	12, 24
		PM ₁₀	---	101.11	6, 12, 13, 14, 19	6, 12, 13, 14, 19, 22, 23	12, 13, 14, 24
		NH ₃	---	29.71	7, 19, 21	19, 21, 22, 23	21
		H ₂ SO ₄	---	0.73	19	19, 22, 23	
		HCl (6)	---	5.89	13, 19	13, 19, 22, 23	13
		Hg	---	0.01	13, 19	13, 19, 22, 23	13
		Pb	---	0.01	19	19, 22, 23	13
B56P9FU01	Piping Fugitives (5)	VOC	1.12	4.90		22	
		NH ₃	0.18	0.79	10	10, 22, 23	
B56P9STL001	Distillate Tank Loading	VOC	2.35	0.18		22	
B56P9ST190	Distillate Storage Tank	VOC	8.34	---		22	
B56P9ST290	Distillate Storage Tank	VOC	8.34	---		22	

Major NSR Summary Table

Permit Number: 46306, PSDTX986, and N059					Issuance Date: 1/31/2017		
Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		Monitoring and Testing Requirements	Recordkeeping Requirements	Reporting Requirements
			lb/hour	TPY (4)	Spec. Cond.	Spec. Cond.	Spec. Cond.
B56P9ST190 and B56P9ST290	Distillate Storage Tanks	VOC	---	0.30		22	
B56CR96 GT-96 and DB96	(Westinghouse 501F Turbine with 735 MMBtu/hr Duct Burner)	NO _x	53.21	122.64	5, 12, 16, 17, 19, 20	12, 16, 17, 19, 20, 22, 23	12, 16, 17, 24, 25
		NO _x (MSS)	140.00				
		CO	218.09	527.28	5, 13, 16, 17, 19, 20	13, 16, 17, 19, 20, 22, 23	13, 16, 17, 25
		CO (MSS)	5000.00				
		VOC	36.40	40.59	16, 19	16, 19, 22, 23	16
		VOC (MSS)	183.49				
		SO ₂	40.14	7.70	8, 12, 16, 19	12, 16, 19, 22, 23	12, 16, 24
		PM ₁₀	32.98	97.94	6, 12, 13, 16, 19	6, 12, 13, 16, 19, 22, 23	12, 13, 16, 24
		NH ₃	27.58	105.94	5, 16, 19, 21	16, 19, 21, 22, 23	16, 21
		NH ₃ (MSS)	50.00				
		H ₂ SO ₄	6.14	1.18	19	19, 22, 23	
		(NH ₄) ₂ SO ₄	8.28	1.59	19	19, 22, 23	
		HCHO	0.53	2.06	13, 16, 19	13, 16, 19, 22, 23	13, 16
		Hg	0.01	0.01	13, 19	13, 19, 22, 23	13
		HCl (6)	11.72	5.89	13, 19	13, 19, 22, 23	13
		Pb	0.01	0.01	13, 19	19, 22, 23	13
B56P9FU01	Piping Fugitives (5)	VOC	2.48	0.01			
		NH ₃	0.01	0.01	10	10, 22, 23	

Footnotes:

(1) Emission point identification - either specific equipment designation or emission point number from plot plan.

(2) Specific point source name. For fugitive sources, use area name or fugitive source name.

(3) NO_x - total oxides of nitrogen

CO - carbon monoxide

VOC - volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1

SO₂ - sulfur dioxide

PM₁₀ - particulate matter (PM) equal to or less than 10 microns in diameter. (NH₄)₂SO₄ emissions are included in PM₁₀ emissions. Where PM is not listed, it shall be assumed that no PM greater than 10 microns is emitted.

NH₃ - ammonia
H₂SO₄ - sulfuric acid mist
(NH₄)₂SO₄ - ammonium sulfate
HCHO - formaldehyde
Hg - mercury
HCl - hydrogen chloride
Pb - lead

(4) Compliance with annual emission limits (tons per year) is based on a 12 month rolling period.

(5) Emission rate is an estimate and is enforceable through compliance with the applicable special condition(s) and permit application representations.

(6) Maximum hourly HCl emissions from all boilers and turbines will not exceed 11.72 pounds per hour. Annual HCl emissions from all boilers and turbines will not exceed 5.89 tons per year.



Texas Commission on Environmental Quality Air Quality Permit

A Permit Is Hereby Issued To
The Dow Chemical Company
Authorizing the Construction and Operation of
Dow Texas Operations Freeport
Located at Freeport, Brazoria County, Texas
Latitude 28° 58' 57" Longitude -95° 21' 21"

Permits: 46306, N059, and PSDTX986

Amendment Date: January 31, 2017

Expiration Date: October 4, 2022

A handwritten signature in black ink, appearing to read "R. D. A. Hyle".

For the Commission

1. **Facilities** covered by this permit shall be constructed and operated as specified in the application for the permit. All representations regarding construction plans and operation procedures contained in the permit application shall be conditions upon which the permit is issued. Variations from these representations shall be unlawful unless the permit holder first makes application to the Texas Commission on Environmental Quality (commission) Executive Director to amend this permit in that regard and such amendment is approved. [Title 30 Texas Administrative Code (TAC) Section 116.116 (30 TAC § 116.116)]¹
2. **Voiding of Permit.** A permit or permit amendment is automatically void if the holder fails to begin construction within 18 months of the date of issuance, discontinues construction for more than 18 months prior to completion, or fails to complete construction within a reasonable time. Upon request, the executive director may grant an 18-month extension. Before the extension is granted the permit may be subject to revision based on best available control technology, lowest achievable emission rate, and netting or offsets as applicable. One additional extension of up to 18 months may be granted if the permit holder demonstrates that emissions from the facility will comply with all rules and regulations of the commission, the intent of the Texas Clean Air Act (TCAA), including protection of the public's health and physical property; and (b)(1) the permit holder is a party to litigation not of the permit holder's initiation regarding the issuance of the permit; or (b)(2) the permit holder has spent, or committed to spend, at least 10 percent of the estimated total cost of the project up to a maximum of \$5 million. A permit holder granted an extension under subsection (b)(1) of this section may receive one subsequent extension if the permit holder meets the conditions of subsection (b)(2) of this section. [30 TAC § 116.120]
3. **Construction Progress.** Start of construction, construction interruptions exceeding 45 days, and completion of construction shall be reported to the appropriate regional office of the commission not later than 15 working days after occurrence of the event. [30 TAC § 116.115(b)(2)(A)]
4. **Start-up Notification.** The appropriate air program regional office shall be notified prior to the commencement of operations of the facilities authorized by the permit in such a manner that a representative of the commission may be present. The permit holder shall provide a separate notification for the commencement of operations for each unit of phased construction, which may involve a series of units commencing operations at different times. Prior to operation of the facilities authorized by the permit, the permit holder shall identify the source or sources of allowances to be utilized for compliance with Chapter 101, Subchapter H, Division 3 of this title (relating to Mass Emissions Cap and Trade Program). [30 TAC § 116.115(b)(2)(B)]
5. **Sampling Requirements.** If sampling is required, the permit holder shall contact the commission's Office of Compliance and Enforcement prior to sampling to obtain the proper data forms and procedures. All sampling and testing procedures must be approved by the executive director and coordinated with the regional representatives of the commission. The permit holder is also responsible for providing sampling facilities and conducting the sampling operations or contracting with an independent sampling consultant. [30 TAC § 116.115(b)(2)(C)]

6. **Equivalency of Methods.** The permit holder must demonstrate or otherwise justify the equivalency of emission control methods, sampling or other emission testing methods, and monitoring methods proposed as alternatives to methods indicated in the conditions of the permit. Alternative methods shall be applied for in writing and must be reviewed and approved by the executive director prior to their use in fulfilling any requirements of the permit. [30 TAC § 116.115(b)(2)(D)]
7. **Recordkeeping.** The permit holder shall maintain a copy of the permit along with records containing the information and data sufficient to demonstrate compliance with the permit, including production records and operating hours; keep all required records in a file at the plant site. If, however, the facility normally operates unattended, records shall be maintained at the nearest staffed location within Texas specified in the application; make the records available at the request of personnel from the commission or any air pollution control program having jurisdiction in a timely manner; comply with any additional recordkeeping requirements specified in special conditions in the permit; and retain information in the file for at least two years following the date that the information or data is obtained. [30 TAC § 116.115(b)(2)(E)]
8. **Maximum Allowable Emission Rates.** The total emissions of air contaminants from any of the sources of emissions must not exceed the values stated on the table attached to the permit entitled "Emission Sources--Maximum Allowable Emission Rates." [30 TAC § 116.115(b)(2)(F)]¹
9. **Maintenance of Emission Control.** The permitted facilities shall not be operated unless all air pollution emission capture and abatement equipment is maintained in good working order and operating properly during normal facility operations. The permit holder shall provide notification in accordance with 30 TAC §101.201, 101.211, and 101.221 of this title (relating to Emissions Event Reporting and Recordkeeping Requirements; Scheduled Maintenance, Startup, and Shutdown Reporting and Recordkeeping Requirements; and Operational Requirements). [30 TAC§ 116.115(b)(2)(G)]
10. **Compliance with Rules.** Acceptance of a permit by an applicant constitutes an acknowledgment and agreement that the permit holder will comply with all rules and orders of the commission issued in conformity with the TCAA and the conditions precedent to the granting of the permit. If more than one state or federal rule or regulation or permit condition is applicable, the most stringent limit or condition shall govern and be the standard by which compliance shall be demonstrated. Acceptance includes consent to the entrance of commission employees and agents into the permitted premises at reasonable times to investigate conditions relating to the emission or concentration of air contaminants, including compliance with the permit. [30 TAC § 116.115(b)(2)(H)]
11. **This** permit may not be transferred, assigned, or conveyed by the holder except as provided by rule. [30 TAC § 116.110(e)]
12. **There** may be additional special conditions attached to a permit upon issuance or modification of the permit. Such conditions in a permit may be more restrictive than the requirements of Title 30 of the Texas Administrative Code. [30 TAC § 116.115(c)]
13. **Emissions** from this facility must not cause or contribute to "air pollution" as defined in Texas Health and Safety Code (THSC) §382.003(3) or violate THSC § 382.085. If the executive director determines that such a condition or violation occurs, the holder shall implement additional abatement measures as necessary to control or prevent the condition or violation.
14. **The** permit holder shall comply with all the requirements of this permit. Emissions that exceed the limits of this permit are not authorized and are violations of this permit.¹

¹ Please be advised that the requirements of this provision of the general conditions may not be applicable to greenhouse gas emissions.

Special Conditions

Permit Numbers 46306, PSDTX986, and N059

Emission Standards and Fuel Specifications

1. This permit covers only those sources of emissions listed in the attached table entitled "Emission Sources - Maximum Allowable Emission Rates," and those sources are limited to the emission limits and other conditions specified in the attached table. The annual rates are based on any consecutive 12-month period.

If one emission rate limitation is more stringent than another emission rate limitation, then the more stringent limitation shall govern and be the standard by which compliance will be demonstrated.

2. Fuel for the four Boilers (Emission Point Nos. (EPNs) B56SB1 through B56SB4), the turbine and the Heat Recovery Steam Generating (HRSG) Duct Burners (EPN B56CR96) authorized by this permit shall be limited to the following:

- A. Pipeline-quality, sweet natural gas containing no more than 5.0 grains total sulfur (hourly basis) and 0.25 grain (annual basis) total sulfur per 100 dry standard cubic feet.
- B. Mixtures of any of the following fuels: pipeline-quality natural gas, off-gas, syngas, cell hydrogen, and PDC hydrogen.

Firing of any other fuel will require authorization from the permitting authority.

3. The heat input for Boilers B56SB1 through B56SB4 shall not exceed 550 MMBtu/hr and 3,346,320 MMBtu/yr per boiler, as determined by the fuel flow at the HHV of the fuel.
4. The duct burner fired HRSG shall be limited to a maximum heat input capacity of 735 MMBtu/hr based on the higher heating value of the fuel fired.
5. The turbine's normal operating range is from 60 to 100 percent of base load except for periods of start-up, shutdown, upset, or maintenance periods. Steam augmentation or reduced load operation below baseload not associated with start-up, shutdown, upset, or maintenance is authorized, provided the maximum nitrogen oxides (NO_x) and ammonia (NH₃) concentrations of this permit condition are not exceeded and provided the NO_x and carbon monoxide (CO) maximum pounds per hour (lbs/hr) emission rates specified in the attached table entitled "Emission Sources - Maximum Allowable Emissions Rates" for EPNs B56CR96 are not exceeded. The NO_x concentrations of

this permit condition shall apply except during periods of start-up, shutdown, or maintenance operations. These periods shall not exceed three hours per event.

The concentration of NO_x in the stack gases from the Cogeneration Train (EPNs B56CR96) shall not exceed a four-hour rolling average concentration of 5 parts per million by volume, dry (ppmvd) and an annual average of 3 ppmvd. The NO_x and CO concentrations measured by the continuous emission monitoring system (CEMS) shall be corrected to 15 percent oxygen (O₂).

The concentrations of NH₃ from the Gas Turbine/HRSGs (EPN B56CR96) shall not exceed 7 ppmvd when corrected to 15 percent O₂ except during periods of start-up, shutdown, upset, or maintenance.

6. Opacity of particulate matter emissions shall not exceed 5 percent from the following Emission Points:

Emission Point Number	Source Name
B56SB1	FB-91 (550MMBtu/hr Boiler)
B56SB2	FB-92 (550MMBtu/hr Boiler)
B56SB3	FB-93 (550MMBtu/hr Boiler)
B56SB4	FB-94 (550MMBtu/hr Boiler)
B56CR96	GT-96 AND DB96 (Westinghouse 501F Turbine with 735 MMBtu/hr Duct Burner)

This determination shall be made by first observing for visible emissions while the facility is in normal operation. Observations shall be made at least 15 feet and no more than 0.25 mile from the emission points. If visible emissions are observed from the stack, then opacity shall be determined by Title 40 Code of Federal Regulations Part 60 (40 CFR Part 60), Appendix A, Test Method (TM) 9. Contributions from uncombined water shall not be included in determining compliance with this condition. Observations shall be performed and recorded quarterly.

7. The three-hour rolling average emissions from each boiler shall not exceed the following limits:

A. NO_x: 0.01 lb/MMBtu.

- B. CO: 50 ppmvd corrected to 3 percent excess O₂.
- C. Ammonia (NH₃): 10 ppmvd corrected to 3 percent excess O₂.

The NO_x heat input-based limit is based upon the HHV of the fuel. Compliance with the emission limits of this special condition shall be based on an hourly average reduced once per day in accordance with Special Condition No. 17.B.

The EPNs B56SB1 through B56SB4 may operate in hot standby mode. During hot standby operation, or during start-up and shutdown of the boiler or the selective catalytic reduction (SCR) system, the heat-based (lb/MMBtu) and concentration-based (ppmvd) emission limits for NH₃, NO_x and CO as stated above do not apply to these emission points. However, the lb/hr and ton per year (TPY) emission rate limits stated on the maximum allowable emission rates table (MAERT) may not be exceeded for any unit under any operating condition.

- 8. Upon request by the Executive Director of the Texas Commission on Environmental Quality (TCEQ) or any air pollution control program having jurisdiction, the holder of this permit shall provide a sample and/or an analysis of the fuel-fired in the gas turbines and duct burners or shall allow air pollution control agency representatives to obtain a sample for analysis.

Anhydrous Ammonia (NH₃)

- 9. In the event of a release of the anhydrous NH₃ from the supply line, vaporizer discharge line, process line to the SCR system, or any other accidental release of anhydrous NH₃, the permit holder shall follow the mitigation procedures set out in the permit application.
- 10. The permit holder shall maintain the piping and valves in NH₃ service as follows:
 - A. All operating practices and procedures relating to the handling of NH₃ shall conform to the safety recommendations specified for that compound by guidelines of the American National Standards Institute and the Compressed Gas Association.
 - B. Audio, olfactory, and visual checks for anhydrous NH₃ leaks within the operating area shall be made once every shift. **(02/15)**
 - C. As soon as practicable, following the detection of a leak, plant personnel shall take one or more of the following actions:
 - (1) Locate and isolate the leak, if necessary.

- (2) Commence repair or replacement of the leaking component.
- (3) Use a leak collection or containment system to control the leak until repair or replacement can be made if immediate repair is not possible.

Date and time of each inspection shall be noted in the operator's log or equivalent. Records shall be maintained at the plant site of all repairs and replacements made due to leaks. These records shall be made available to representatives of the Texas Commission on Environmental Quality (TCEQ) upon request.

Nonattainment New Source Review (NNSR) - Emission Reductions (02/15)

11. This NNSR permit is issued based on the permanent retirement of 105.89 tpy of volatile organic compounds (VOC) emissions reductions from TCEQ issued ERCCs. These ERCCs provide offsets at the rate of 1.3:1.0 for the 81.45 tpy of VOC emissions from the turbines authorized under this permit.

*The holder of this permit submitted Form EC-3 (Notice of Intent to Use Emission Credits) on August 8, 2006 to satisfy the terms of Special Condition No. 11.

Federal Applicability

12. These facilities shall comply with applicable requirements of the EPA regulations in Title 40 Code of Federal Regulations (40 CFR) Part 60 on Standards of Performance for New Stationary Sources promulgated for:
 - A. Applicable General Conditions, Subpart A.
 - B. The boilers and duct burner-fired HRSG are subject to the applicable requirements of Subpart Db, Standards of Performance for Industrial-Commercial-Institutional Stream Generating Units.
 - C. The gas turbine is subject to the applicable requirements of Subpart KKKK, Standards of Performance for Stationary Combustion Turbines.

Special Conditions

Permit Numbers 46306, PSDTX986, and N059

Page 5

13. These facilities shall comply with all applicable requirements of the U.S. Environmental Protection Agency (EPA) regulations on National Emission Standards for Hazardous Air Pollutants for Source Categories in 40 CFR Part 63:
 - A. Subpart A, General Provisions.
 - B. Subpart YYYY - National Emission Standards For Hazardous Air Pollutants For Stationary Combustion Turbines
 - C. Subpart DDDDD - National Emission Standards For Hazardous Air Pollutants For Industrial, Commercial, And Institutional Boilers And Process Heaters
 - D. Subpart GGGGG—National Emissions Standards for Hazardous Air Pollutants for Site Remediation

If any condition of this permit is more stringent than the regulations so incorporated, then for the purposes of complying with this permit, the permit shall govern and be the standard by which compliance shall be demonstrated.

Initial Determination of Compliance - Boilers

14. The holder of this permit shall perform stack sampling and other testing as required to establish the actual pattern and quantities of air contaminants being emitted into the atmosphere by the boilers. Sampling of at least one of the Boilers (EPNs B56SB1 through B56SB4) shall be conducted while firing a mixture of natural gas and the fuels listed in Special Condition No. 2.B. The testing required by this special condition for NO_x and CO shall be used to determine initial compliance with the limits specified in the MAERT. Initial compliance with the permit opacity limit of Special Condition No. 6 shall be demonstrated on the basis of compliance with 40 CFR Part 60.11(b). Sampling must be conducted in accordance with appropriate procedures of the TCEQ Sampling Procedures Manual and in accordance with the EPA Reference Method 9 for opacity, Reference Method 10 for CO, Reference Method 7E for NO_x, and Reference Method 3 for O₂ or equivalent methods.

The holder of this permit is responsible for providing sampling and testing facilities and conducting the sampling and testing operation at his/her expense.

- A. The TCEQ Houston Regional Office shall be contacted as soon as testing is scheduled but not less than 30 days prior to sampling to schedule a pretest meeting. The notice shall include:

- (1) Date for pretest meeting.
- (2) Date sampling will occur.
- (3) Name of firm conducting sampling.
- (4) Type of sampling equipment to be used.
- (5) Method or procedure to be used in sampling.
- (6) Proposed method of demonstrating compliance with 40 CFR § 60.48b.

The purpose of the pretest meeting is to review the necessary sampling and testing procedures, to provide the proper data forms for recording pertinent data, and to review the format procedures for submitting the test reports.

A written proposed description of any deviation from sampling procedures specified in permit conditions or TCEQ or EPA sampling procedures shall be made available to the TCEQ prior to the pretest meeting. The TCEQ Regional Director shall approve or disapprove of any deviation from specified sampling procedures.

Requests to waive testing for any pollutant specified in Special Condition No.14.B shall be submitted to the TCEQ Office of Air, Air Permits Division. Test waivers and alternate or equivalent procedure proposals for New Source Performance Standards (NSPS) testing which must have EPA approval shall be submitted to the TCEQ regional office.

- B. The air contaminants emitted from the boilers to be tested for at the maximum firing rate specified in Special Condition No. 3 include (but are not limited to) NO_x, CO, O₂, particulate matter equal to or less than 10 microns in diameter (PM₁₀), and opacity. If the boilers are unable to reach the maximum firing rate during testing, then future firing may be limited to the highest firing rate achieved during testing. Furthermore, if the boilers are unable to comply with the emission limits of this permit for any or all of the pollutants of this permit while operating at maximum firing during the test, then future firing will be limited to the maximum emissions-complying firing tested. Additional stack testing may be required for higher firing outside the emissions-complying maximum achieved during the test to be authorized.
- C. Sampling with natural gas fuel shall occur within 60 days after the facilities achieve maximum production but not later than 180 days after initial start-up of the facilities and at such other times as may be required

by the Executive Director of the TCEQ. Sampling with additional fuels as listed in Special Condition No. 2.B will be conducted within 60 days after the facilities achieve maximum production with that fuel but not later than 180 days after initial use of the fuel. Requests for additional time to perform stack sampling shall be submitted to the TCEQ Regional Office. Additional time to comply with the applicable requirements of 40 CFR Part 60 require EPA approval, and requests shall be submitted to the TCEQ regional office.

- D. Copies of the final sampling report shall be forwarded to the TCEQ within 60 days after sampling is completed. Sampling reports shall comply with the attached provisions of Chapter 14 of the TCEQ Sampling Procedures Manual. The reports shall be distributed as follows:

One copy to the TCEQ Houston Regional Office

One copy to the TCEQ Office of Air, Air Permits Division in Austin

One copy to the appropriate local programs

Initial Determination of Compliance - Turbines

15. Sampling ports and platforms shall be incorporated into the design of all exhaust stacks according to the specifications set forth in the attachment entitled "Chapter 2, Stack Sampling Facilities." Alternate sampling facility designs may be submitted for approval by the TCEQ Regional Director.
16. The holder of this permit shall perform stack sampling and other testing as required to establish the actual quantities of air contaminants being emitted into the atmosphere from EPN B56CR96. Sampling of at least one of the above cogeneration trains shall be conducted while firing a mixture of natural gas and the additional fuels listed in Special Condition No. 2.B. Sampling shall be conducted in accordance with the appropriate procedures of the TCEQ Sampling Procedures Manual and in accordance with the appropriate EPA Reference Methods 201A and 202 or Reference Method 5, modified to include back-half condensibles, for the concentration of PM₁₀; Reference Method 8 or Reference Methods 6 or 6c for sulfur dioxide (SO₂); Reference Method 9 for opacity (consisting of 30 six-minute readings as provided in 40 CFR § 60.11[b]); Reference Method 10 for the concentration of CO, Reference Method 25A, modified to exclude methane and ethane, for the concentration of VOC (to measure total carbon as propane); and Reference Method 20 for the concentrations of NO_x and O₂ or equivalent methods.

Fuel sampling using the methods and procedures of 40 CFR § 60.4360 may be conducted in lieu of stack sampling for SO₂. If fuel sampling is used, compliance with NSPS, Subpart KKKK, SO₂ limits shall be based on 100 percent conversion of the sulfur in the fuel to SO₂. Any deviations from those procedures must be approved by the Executive Director of the TCEQ prior to sampling. The TCEQ Executive Director or his designated representative shall be afforded the opportunity to observe all such sampling.

The holder of this permit is responsible for providing sampling and testing facilities and conducting the sampling and testing operations at his expense.

A. The TCEQ Houston Regional Office shall be contacted as soon as testing is scheduled but not less than 30 days prior to sampling to schedule a pretest meeting. The notice shall include:

- (1) Date for pretest meeting.
- (2) Date sampling will occur.
- (3) Name of firm conducting sampling.
- (4) Type of sampling equipment to be used.
- (5) Method or procedure to be used in sampling.
- (6) Procedure used to determine turbine loads during and after the sampling period.

The purpose of the pretest meeting is to review the necessary sampling and testing procedures, to provide the proper data forms for recording pertinent data, and to review the format procedures for submitting the test reports. A written proposed description of any deviation from sampling procedures specified in permit conditions or TCEQ or EPA sampling procedures shall be made available to the TCEQ prior to the pretest meeting. The TCEQ Regional Director shall approve or disapprove of any deviation from specified sampling procedures. Requests to waive testing for any pollutant specified in this condition shall be submitted to the TCEQ Office of Permitting and Registration, Air Permits Division. Test waivers and alternate or equivalent procedure proposals for NSPS testing which must have EPA approval shall be submitted to the TCEQ regional office.

B. Each turbine shall be tested at a minimum (VOC only) and maximum load of the permitted operating range that is defined in Special Condition No. 5 for the atmospheric conditions which exist during testing. The duct burners shall be tested at its maximum firing rate while the turbine is operating as close to base load as possible. Each tested turbine load shall

be identified in the sampling report. The permit holder shall present at the pretest meeting the manner in which stack sampling will be executed in order to demonstrate compliance with emission standards found in NSPS Subparts Db and KKKK.

- C. Air contaminants and diluents to be sampled and analyzed include (but are not limited to) NO_x, CO, VOC, SO₂, PM₁₀, NH₃, opacity, formaldehyde, and O₂. (As noted above, fuel sampling using the methods and procedures of 40 CFR § 60.4630 may be conducted in lieu of stack sampling for SO₂.) The PM₁₀ shall be tested at one point in the turbine permitted operating range while the turbine is operating as close to base load as possible and while the duct burners are operating at their maximum firing rate.
- D. Sampling with natural gas fuel as required by this condition shall occur within 60 days after achieving the maximum fuel-firing rate at which the turbines and duct burners will be operated but no later than 180 days after initial start-up of each cogeneration unit. Sampling with additional fuels as listed in Special Condition No. 2.B will be conducted within 60 days after the facilities achieve maximum production with that fuel but not later than 180 days after initial use of that fuel. Additional sampling shall occur as may be required by the TCEQ or EPA.
- E. Within 60 days after the completion of the testing and sampling required herein, copies of the sampling reports shall be distributed as follows:

One copy to the EPA Region 6 Office, Dallas.

One copy to the TCEQ Houston Regional Office.

Continuous Determination of Compliance

- 17. The holder of this permit shall install, calibrate, maintain, and operate a CEMS to measure and record the concentrations of NO_x, CO, and diluent gases (Oxygen [O₂] or carbon dioxide [CO₂]) from each boiler and each turbine.
 - A. The CEMS shall meet the design and performance specifications, pass the field tests, and meet the installation requirements and the data analysis and reporting requirements specified in the applicable Performance Specification Nos. 1 through 9, 40 CFR Part 60, Appendix B, or an acceptable alternative. If there are no applicable performance specifications in 40 CFR Part 60, Appendix B, contact the TCEQ Office of Air, Air Permits Division in Austin for requirements to be met. The CEMS shall comply with the following requirements:

The holder of this permit shall assure that the CEMS meets the applicable quality-assurance requirements specified in 40 CFR Part 60, Appendix F, Procedure 1, or an acceptable alternative. Relative accuracy exceedances, as specified in 40 CFR Part 60, Appendix F, § 5.2.3, shall be met with an alternative relative accuracy allowable of no more than 2 ppm calculated as the absolute value of the arithmetic mean of the difference between RM and CEMS plus the 2.5 percent error confidence coefficient. Any CEMS downtime and all cylinder gas audit exceedances of ≥ 15 percent accuracy shall be reported semiannually to the appropriate TCEQ Regional Director, and necessary corrective action shall be taken. Supplemental stack concentration measurements may be required at the discretion of the appropriate TCEQ Regional Director.

- B. The monitoring data shall be reduced to hourly average values at least once every day, using a minimum of four equally-spaced data points from each one-hour period. At least two valid data points shall be generated during the hourly period in which zero and span is performed.
 - C. All monitoring data and quality-assurance data shall be maintained by the source for a period of five years and shall be made available to the TCEQ Executive Director or a designated representative upon request. The hourly average data from the CEMS may be used to determine compliance with the conditions of this permit. Hourly average concentrations from the boilers and turbines shall be summed to TYPY each month and used to determine compliance with the emission limits of this permit.
 - D. The appropriate TCEQ Regional Office shall be notified at least 21 days prior to any required relative accuracy test audits in order to provide them the opportunity to observe the testing.
 - E. If applicable, the CEMS for the boilers and turbines may be required to meet the design and performance specifications, pass the field tests, and meet the installation requirements and data analysis and reporting requirements specified in the applicable performance specifications in 40 CFR Part 75, Appendix A. Title 40 CFR Part 75 is deemed an acceptable alternative to the performance specifications and quality-assurance requirements of 40 CFR Part 60.
18. If any emission monitor fails to meet specified performance, it shall be repaired or replaced as soon as reasonably possible.

Special Conditions

Permit Numbers 46306, PSDTX986, and N059

Page 11

19. The holder of this permit shall additionally install, calibrate, maintain, and operate continuous monitoring systems to monitor and record the average hourly natural gas and plant fuel gas consumption of the boilers, the turbines, and the duct burners. The systems shall be accurate to ± 5.0 percent of the units' maximum flow.
20. The holder of this permit shall either measure or develop a program to calculate the total mass flow rate through the HRSG stack to ensure continuous compliance with the emission limitations specified in the attached table entitled "Emission Sources - Maximum Allowable Emission Rates." The permit holder shall calculate hourly mass emissions in lbs/hr using the measured or calculated exhaust flow rate and the measured concentrations of NO_x and CO from the CEMS required in Special Condition No. 17. The hourly calculated values will be cumulatively added during each hour of the month and stored on a computer hard drive and on computer disk or other TCEQ-accepted computer media. Records of this information shall also be available in a form suitable for inspection.
21. The NH_3 concentration in each boiler and turbine exhaust stack shall be tested or calculated according to one of the methods listed below and shall be tested or calculated according to frequency listed below. Testing for NH_3 slip is only required on days when the SCR unit is in operation.
 - A. The holder of this permit may install, calibrate, maintain, and operate a CEMS to measure and record the concentrations of NH_3 . The NH_3 concentrations shall be corrected and reported in accordance with Special Nos. 5 and 7.
 - B. As an approved alternative, the NH_3 slip may be measured using a sorbent or stain tube device specific for NH_3 measurement in the 5 to 10 parts per million (ppm) range. The frequency of sorbent or stain tube testing shall be daily for the first 60 days of operation, after which the frequency may be reduced to weekly testing if operating procedures have been developed to prevent excess amounts of NH_3 from being introduced in the SCR unit and when operation of the SCR unit has been proven successful with regard to controlling NH_3 slip. Daily sorbent or stain tube testing shall resume when the catalyst is within 30 days of its useful life expectancy. These results shall be recorded and used to determine compliance with Special Condition Nos. 5 and 7.
 - C. As an approved alternative to sorbent or stain tube testing or an NH_3 CEMS, the permit holder may install and operate a second NO_x CEMS

probe located between the firebox and the SCR, upstream of the stack NO_x CEMS, which may be used in association with the SCR efficiency and NH₃ injection rate to estimate NH₃ slip. This condition shall not be construed to set a minimum NO_x reduction efficiency on the SCR unit. These results shall be recorded and used to determine compliance with Special Condition Nos. 5 and 7.

- D. If the sorbent or stain tube testing indicates an NH₃ slip concentration which exceeds 5 ppm at any time, the permit holder shall begin NH₃ testing by either the Phenol-Nitroprusside Method, the Indophenol Method, or the EPA Conditional Test Method (CTM) 27 on a quarterly basis, in addition to the weekly sorbent or stain tube testing. The quarterly testing shall continue until such time as the SCR unit catalyst is replaced; or if the quarterly testing indicates NH₃ slip is 4 ppm or less, the Phenol-Nitroprusside/Indophenol/CTM 27 tests may be suspended until sorbent or stain tube testing again indicate 5 ppm NH₃ slip or greater. These results shall be recorded and used to determine compliance with Condition Nos. 5 and 7.
- E. As an approved alternative to sorbent or stain tube testing, NH₃ CEMS, or a second NO_x CEMS, the permit holder may install and operate a dual stream system of NO_x CEMS at the exit of the SCR. One of the exhaust streams would be routed, in an unconverted state, to one NO_x CEMS; and the other exhaust stream would be routed through a NH₃ converter to convert NH₃ to NO_x and then to a second NO_x CEMS. The NH₃ slip concentration shall be calculated from the delta between the two NO_x CEMS readings (converted and unconverted). These results shall be recorded and used to determine compliance with Special Condition Nos. 5 and 7.
- F. Any other method used for measuring NH₃ slip shall require prior approval from the TCEQ Houston Regional Office.

Recordkeeping Requirements

- 22. The following records shall be kept at the plant for the life of the permit. All records required in this permit shall be made available at the request of personnel from the TCEQ or any air pollution control agency with jurisdiction.
 - A. A copy of this permit.
 - B. Permit application dated November 2000 and subsequent representations submitted to the TCEQ.

- C. A complete copy of the testing reports and records of the initial performance testing completed pursuant to Special Condition Nos. 14 and 16 to demonstrate initial compliance.
 - D. Stack sampling results or other air emissions testing (other than CEMS data) that may be conducted on units authorized under this permit after the date of issuance of this permit.
23. The following information shall be maintained by the holder of this permit in a form suitable for inspection for a period of five years after collection and shall be made immediately available upon request to representatives of the TCEQ or any air pollution control agency with jurisdiction.
- A. The NO_x, CO, and dilutant gases, O₂ or CO₂, CEMS emissions data to demonstrate compliance with the emission rates listed in the MAERT.
 - B. Raw data files of all CEMS data including calibration checks and adjustments and maintenance performed on these systems.
 - C. Records of NH₃ emissions sampling and calculations pursuant to Special Condition No. 21.
 - D. Written records of any accidental releases, spills, or venting of NH₃ and the corrective action taken in accordance with Special Condition No. 9.
 - E. Written records of maintenance performed to any piping and valves in anhydrous NH₃ service pursuant to Special Condition No. 10.
 - F. Records of the hours of operation and average daily quantity of natural gas and by-product hydrogen fired in the boilers and the turbines and HRSG duct burners.
 - G. Monthly records of the average feed rate of each type of plant fuel gas in lbs/hr, the corresponding average HHV of each plant fuel gas in MMBtu/hr, each plant fuel gas composition calibrated as weight percent hydrogen, the natural gas flow measured in a 1,000 standard cubic feet per hour, and the combined average heat input in MMBtu/hr of each plant fuel gas and natural gas to show compliance with Special Condition No. 3.
 - (1) The monthly rolling average of the feed rate is the arithmetic mean of the monthly 60-minute averages beginning and ending during each monthly operating period.

- (2) The combined heat input (in MMBtu/hr) of plant fuel gas shall be continuously monitored and recorded at a minimum of four equally-spaced intervals per hour and averaged at least every 60 minutes.
- H. Records of fuel sampling conducted pursuant to 40 CFR Part 60, Subpart KKKK.
- I. Records of visible observations pursuant to Special Condition 6.
- J. Records of AVO inspections pursuant to Special Condition 10.

Reporting

- 24. The holder of this permit shall submit to the TCEQ Houston Regional Office and the Air Enforcement Branch of EPA in Dallas reports as described in 40 CFR § 60.7 in accordance with NSPS requirements. Such reports are required for each emission unit which is required to be continuously monitored pursuant to this permit.
- 25. If the NO_x or CO maximum allowable emissions rates are exceeded for more than three hours, the holder of this permit shall investigate and determine the reason for the exceedance and, if needed, make necessary repairs and/or adjustments as soon as possible. If the above NO_x or CO exceedance occurs for more than 24 hours, the permit holder shall notify the TCEQ Regional Office either verbally or with a written report detailing the cause of the increase in emissions, and all efforts being made to correct the problem.
- 26. This permit is conditioned on the completion of all emission reduction projects represented in the permit application as follows: **(02/15)**
 - A. Projects represented in the Table 2N "Project Contemporaneous Changes" submitted on August 14, 2002 and found in Section 2 of the permit application for the boilers.
 - B. Projects represented in the Table 2N "Project Contemporaneous Changes" submitted on May 27, 2004 for NO_x and July 1, 2004 for VOC and found in Section 2 of the permit application for the turbines.

This reduction of emissions shall occur not later than the commencement of operation of these Permitted facilities, plus a reasonable shakedown period, not to exceed 180 days. The holder of this permit shall maintain records of these emission reductions and provide access and/or copies

upon request to the TCEQ Executive Director or a representative or any local air pollution control program having jurisdiction. Construction of these facilities must commence as defined in 40 CFR § 52.21(b)(9) (PSD) or 40 CFR § 51.165(a)(1)(xvi) (Nonattainment) no later than five years after the reductions are actually accomplished, or the above reductions are no longer creditable, and the permit is automatically void.

*To satisfy the terms of Special Condition No. 26 NO_x reductions were made enforceable via Permit No. 9044 issued September 3, 2002 and Permit No. 9046 issued September 3, 2002. VOC reductions were made enforceable via Permit No. 20432 Chapter III issued November 25, 2002.

Date: February 18, 2015

Emission Sources - Maximum Allowable Emission Rates

Permit Numbers 46306, PSDTX986, and N059

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities, sources, and related activities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

Air Contaminants Data

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY (4)
B56SB1	FB-91 (550 MMBtu/hr Boiler)	NO _x	5.50	-
		CO	20.05	-
		VOC	2.97	-
		SO ₂	7.79	-
		PM ₁₀	9.44	-
		NH ₃	2.44	-
		H ₂ SO ₄	1.19	-
		HCl (6)	11.72	-
		Hg	0.01	-
		Pb	0.01	-
B56SB2	FB-92 (550 MMBtu/hr Boiler)	NO _x	5.50	-
		CO	20.05	-
		VOC	2.97	-
		SO ₂	7.79	-
		PM ₁₀	9.44	-
		NH ₃	2.44	-
		H ₂ SO ₄	1.19	-
		HCl (6)	11.72	-
		Hg	0.01	-
		Pb	0.01	-

Emission Sources - Maximum Allowable Emission Rates

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY (4)
B56SB3	FB-93 (550 MMBtu/hr Boiler)	NO _x	5.50	-
		CO	20.05	-
		VOC	2.97	-
		SO ₂	7.79	-
		PM ₁₀	9.44	-
		NH ₃	2.44	-
		H ₂ SO ₄	1.19	-
		HCl (6)	11.72	-
		Hg	0.01	-
		Pb	0.01	-
B56SB4	FB-94 (550 MMBtu/hr Boiler)	NO _x	5.50	-
		CO	20.05	-
		VOC	2.97	-
		SO ₂	7.79	-
		PM ₁₀	9.44	-
		NH ₃	2.44	-
		H ₂ SO ₄	1.19	-
		HCl (6)	11.72	-
		Hg	0.01	-
		Pb	0.01	-

Emission Sources - Maximum Allowable Emission Rates

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY (4)
B56SB1, BP9SB2, B56SB3, & B56SB4	FB-91, 92, 93, and 94	NO _x	-	66.93
		CO	-	244.29
		VOC	-	36.14
		SO ₂	-	4.74
		PM ₁₀	-	101.11
		NH ₃	-	29.71
		H ₂ SO ₄	-	0.73
		HCl (6)	-	5.89
		Hg	-	0.01
		Pb	-	0.01
B56P9FU01	Piping Fugitives (5)	VOC	1.12	4.90
		NH ₃	0.18	0.79
B56P9STL001	Distillate Tank Loading	VOC	2.35	0.18
B56P9ST190	Distillate Storage Tank	VOC	8.34	-
B56P9ST290	Distillate Storage Tank	VOC	8.34	-
B56P9ST190 and B56P9ST290	Distillate Storage Tanks	VOC	-	0.30

Emission Sources - Maximum Allowable Emission Rates

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY (4)
B56CR96	GT-96 and DB96 (Westinghouse 501F Turbine with 735 MMBtu/hr Duct Burner)	NO _x	53.21	122.64
		NO _x (MSS)	140.00	
		CO	218.09	527.28
		CO (MSS)	5000.00	
		VOC	36.40	40.59
		VOC (MSS)	183.49	
		SO ₂	40.14	7.70
		PM ₁₀	32.98	97.94
		NH ₃	27.58	105.94
		NH ₃ (MSS)	50.00	
		H ₂ SO ₄	6.14	1.18
		(NH ₄) ₂ SO ₄	8.28	1.59
		HCHO	0.53	2.06
		Hg	0.01	0.01
		HCl (6)	11.72	5.89
		Pb	0.01	0.01
B56P9FU01	Piping Fugitives (5)	VOC	2.48	0.01
		NH ₃	0.01	0.01

- (1) Emission point identification - either specific equipment designation or emission point number from plot plan.
- (2) Specific point source name. For fugitive sources, use area name or fugitive source name.
- (3) NO_x - total oxides of nitrogen
CO - carbon monoxide
VOC - volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1
SO₂ - sulfur dioxide

Emission Sources - Maximum Allowable Emission Rates

PM₁₀ - particulate matter (PM) equal to or less than 10 microns in diameter. (NH₄)₂SO₄ emissions are included in PM₁₀ emissions. Where PM is not listed, it shall be assumed that no PM greater than 10 microns is emitted.

NH₃ - ammonia

H₂SO₄ - sulfuric acid mist

(NH₄)₂SO₄ - ammonium sulfate

HCHO - formaldehyde

Hg - mercury

HCl - hydrogen chloride

Pb - lead

- (4) Compliance with annual emission limits (tons per year) is based on a 12 month rolling period.
- (5) Emission rate is an estimate and is enforceable through compliance with the applicable special condition(s) and permit application representations.
- (6) Maximum hourly HCl emissions from all boilers and turbines will not exceed 11.72 pounds per hour. Annual HCl emissions from all boilers and turbines will not exceed 5.89 tons per year.

Date: January 31, 2017